



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

8/29/2022

SUBJECT: SFD2203-0001
SINGLE FAMILY DWELLING

To: My The Vo

Here are the results of all Inspections located at **144 CROWNVIEW LN:**

Inspection Type: FOUNDATION SURVEY
Scheduled Date/Time:
Completed Date/Time:
Inspector: CP Bucket
Result:
Remarks: not required
Notes:

Inspection Type: WATER CONNECTION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: TEMP POWER CERTIFICATION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: FINAL SFD STEMWALL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: SEWER CONNECTION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: ADDRESS
Scheduled Date/Time: 5/2/2022
Completed Date/Time: 5/4/2022
Inspector: GIS Bucket
Result: APPROVED
Remarks:
Notes: 144 CROWN VIEW LN DUNN 28334.

Inspection Type: FOOTING SFD STEMWALL
Scheduled Date/Time: 5/3/2022
Completed Date/Time: 5/3/2022
Inspector: Deen Taylor
Result: APPROVED
Remarks:
Notes:

Inspection Type: T-POLE
Scheduled Date/Time: 5/9/2022
Completed Date/Time: 5/9/2022
Inspector: Deen Taylor
Result: APPROVED
Remarks:
Notes:

Inspection Type: FOUNDATION SFD STEMWALL
Scheduled Date/Time: 5/9/2022
Completed Date/Time: 5/9/2022
Inspector: Deen Taylor
Result: APPROVED
Remarks:
Notes:





Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: UNDER SLAB TRADES SFD STEMWALL
Scheduled Date/Time: 5/23/2022
Completed Date/Time: 5/23/2022
Inspector: Deen Taylor
Result: APPROVED
Remarks:
Notes:

Inspection Type: SEWER CONNECTION
Scheduled Date/Time: 5/25/2022
Completed Date/Time: 5/25/2022
Inspector: Deen Taylor
Result: CANCELLED
Remarks:
Notes:

Inspection Type: SLAB SFD STEMWALL
Scheduled Date/Time: 5/25/2022
Completed Date/Time: 5/25/2022
Inspector: Deen Taylor
Result: APPROVED
Remarks:
Notes:

Inspection Type: ROUGH IN SFD STEMWALL
Scheduled Date/Time: 7/19/2022
Completed Date/Time: 7/19/2022
Inspector: Deen Taylor
Result: DISAPPROVED
Remarks:
Notes: Fire block area between kitchen and laundry room at top plate. Fill all the holes in the slab for plumbing with concrete. OK to insulate

Inspection Type: INSULATION SFD STEMWALL
Scheduled Date/Time: 7/21/2022
Completed Date/Time: 7/21/2022
Inspector: Deen Taylor
Result: APPROVED
Remarks:
Notes:





Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: ROUGH IN REINSPECT

Scheduled Date/Time: 7/21/2022

Completed Date/Time: 7/21/2022

Inspector: Deen Taylor

Result: APPROVED

Remarks:

Notes:

Inspection Type: ENVIR OPERATIONS PERMIT

Scheduled Date/Time: 8/26/2022

Completed Date/Time: 8/26/2022

Inspector: Andrew Currin

Result: APPROVED

Remarks:

Notes: