


System: ———
 Repair: - - - -

- *Keep tanks and drain lines 10' from property lines.
- *Not a survey.
- *Not a guarantee of a septic permit.
- *Keep supply lines >5' from property lines.
- *Some lines are flagged longer in the field than lengths indicate.
- *No grading septic area.

System: Gravity to D-Box Lines: 2-5, (4x75'x3') EZ Flow 0.4 Soil LTAR 24" Trench Bottom
Repair: Gravity to Serial Dist. Lines: 6-10, (321') EZ Flow 0.4 Soil LTAR 24" Trench Bottom



Central Carolina Soil Consulting, PLLC
 1900 South Main Street, Suite 110
 Wake Forest, North Carolina 27587
 Phone (919)569-6704 Fax (919)569-6703

4-Bedroom Septic Layout
 Lot 3, Birchwood Subdivision
 Wake County, North Carolina

Job# : 3753
Drawn By : LW
Date : 08/17/2021
Revision: