

March 24, 2022

Austin Robertson Halcyon Homes arobertson@halcyonhomesnc.com

Re: Foundation Inspection

4 Prince Place

Harnett County, North Carolina

GeoTechnologies Project No. 1-22-0248-EA

Gentlemen:

GeoTechnologies, Inc. has completed the authorized footing inspection for the residential structure under construction on Lot 4 at Prince Place in Harnett County, North Carolina. Third party inspection was conducted and verification of foundation projections, perimeter CMU walls including interior CMU columns, and anchor bolts were in accordance with plans provided on-site.

GeoTechnologies, Inc. appreciates the opportunity to provide you with our services during this phase of the project. Please contact us if you should have questions regarding this information or if we may be of further assistance.

Sincerely,

GeoTechnologies, Inc.

Ernest L. Stitzinger, P.E.

NC Registration No. 25534

DESIGN PROFESSIONAL INSPECTION FORM

RECORD OF THE INSPECTION OF A **COMPONENT OR ELEMENT** BY A NC LICENSED ARCHITECT OR **ENGINEER**

Project Information:

Residential Single-Family Project: Y	ial Single-Family Project: Y Commercial Project: N		
Code Enforcement Project No:	Permit No: SFD2203-0031		
Project Name: 4 Prince Place	Owner: Halcyon Homes		
Project Address: 87 Prince Place Drive	Suite No:		
Date Inspected: 3/24/2022	Contractor Name: Halcyon Homes		
Component Inspected: Foundation Inspec	ection/plan		

Responsible Licensed NC Architect or NC Engineer

Name:	Ernest L. Stitzinger, P.E.		
Firm Name:	GeoTechnologies		
Phone Numbers:	Office: 919 954-1514	Mobile:	919 815-8270
Email Address:	estitzinger@geotechpa.c	om	
Mailing Address:	3200 Wellington Ct./Suite 108/Raleigh/NC/27615		

APPLICABLE CODE:	2018 NCRC	
2018 NCBC = 2018 NC E	Building Code; 2018 NCRO	C = 2018 NC Residential Code
	emponent/Type of Inspect	

^{*(}subgrade form/letter may also be required)

Attestation/Signature:

By signing below, I certify that the component and/or element of the building as identified on this form has been inspected by me or someone under my direct supervision per subsection (b2) of NC G.S. 153A-352 and is in compliance with the Code or other proposal of the architect or engineer for the project. This inspection is in compliance with all of the requirements of the above referenced

Code. Attach any additional documents if needed.

Licensed Architect or Engineer

Inspection Department disclaimer:

Upon the receipt of a signed written document as required under subsection (a) of Article 160A-413.5., Code Enforcement shall be discharged and released from any liabilities, duties and responsibilities imposed by this article or in common law from any claim arising out of or attributed to the component or element in the construction of the building for which the signed written document was submitted. Be aware that this inspection will be noted in all inspection records including the Certificate of Occupancy or Certificate of Compliance. This inspection does not address any local ordinances or zoning requirements.

SEAL