



Components Division
Dunn NC #2383
200 Emmett Rd, Dunn NC 28334
910-892-8400

8/12/22

To Whom It May Concern,

After reviewing the information, this letter is to address the concern about the roof trusses at 102 Birchwood Grove, for KB Homes.

The repair of $\frac{3}{4}$ " OSB on both sides of the damaged truss is not affected in any way with the modification observed on site to accommodate electrical run. Truss will perform as designed. Please reach out if any other information is required.

Thank You

Del Oldland
Components Territory Manager
(910) 892-8400