



Components Division
Dunn NC #2383
200 Emmett Rd, Dunn NC 28334
910-892-8400

10/11/22

To Whom It May Concern,

After reviewing the information, this letter is to address the roof trusses for the KB Homes job, Lot 72 Birchwood Grove.

In reference to the HG truss where the top chord is cracked. Please refer to the sealed standard repair detail for field correction. This truss will perform as designed. Please feel free to reach out if you have any questions or concerns.

Thank You

Del Oldland
Components Territory Manager
(910) 892-8400