

North Carolina State Laboratory of Public Health

Environmental Sciences

Inorganic Chemistry

Certificate of Analysis

4312 District Drive MSC 1918 Raleigh, NC 27699-1918

http://slph.ncpublichealth.com Phone: 919-733-7308 Fax: 919-715-8611

FINAL REPORT

Report to: James E Manhart III

HARNETT CO ENVIRONMENTAL HEALTH

307 CORNELIUS HARNETT BLVD

LILLINGTON, NC 27546

Name of System:

Cumberland Homes Inc

64 Old Hamilton Rd Dunn, NC 28334

EIN: 566000306EH Delivery: NC Courier

StarLiMS ID: ES230412-0021 Date Collected: 04/11/2023 Time Collected: 10:00 By: James E Manhart III

Date Received: 04/12/2023 Time Received: 07:43

Sample Type: Raw Sampling Point: Outside spigot Well Permit No.

Sample Source: New Well Receipt Temp.: 3.0 °C GPS Number:

Profile: New Well I

Analyte	Test Result	Allowable Limit	Unit	Qualifier(s)
Arsenic	<0.001	0.010	mg/L	
Barium	0.223	2.0	mg/L	
Cadmium	<0.0005	0.005	mg/L	
Calcium	7		mg/L	
Chloride	10.2	250	mg/L	
Chromium	<0.02	0.10	mg/L	
Copper	0.010	1.3	mg/L	
Fluoride	<0.1	4.00	mg/L	
Iron	<0.06	0.30	mg/L	
Lead	<0.003	0.015	mg/L	
Magnesium	3		mg/L	
Manganese	0.054	0.05	mg/L	
Mercury	<0.0004	0.002	mg/L	
Nickel	<0.01	0.1	mg/L	
Nitrate	8.22	10.0	mg/L	
Nitrite	<0.1	1.00	mg/L	
рН	5.2		N/A	
Selenium	<0.005	0.05	mg/L	
Silver	<0.01	0.10	mg/L	
Sodium	2.3		mg/L	
Sulfate	<5	250	mg/L	
Total Alkalinity	<1		mg/L	
Total Hardness	31		mg/L	
Zinc	0.07	5.0	mg/L	

Report Date: 04/25/2023

Reported By:

Marc Komlos



Private Well Information and Use Recommendations

For Ingramic Chamical Contaminants

For morganic Chemical Contaminants
County: HARNEII Sample Name: Cunterland Hora 64 018 Hamilton 12
Sample ID #: ES 230412-002/ Reviewer: Im/ Manc Kombos
TEST RESULTS AND USE RECOMMENDATIONS 1. Your well water meets federal drinking water standards <i>for inorganic chemicals</i> . Your water can be used for drinking, cooking, washing, cleaning, bathing, and showering based on the <i>inorganic chemical results only</i> . You may have other water sampling results that are not taken into account in this report.
2. The following substance(s) exceeded federal drinking water standards or the North Carolina 2L calculated health levels. The North Carolina Division of Public Health recommends that your well water not be used for drinking and cooking unless you install a water treatment system to remove the checked substance(s). However, it may be used for washing, cleaning, bathing, and showering based on the <i>inorganic chemical results only</i> . Arsenic Barium Cadmium Chromium Copper Fluoride Iron
□ Lead □ Manganese □ Mercury □ Nickel □ Nitrate/Nitrite □ Selenium □ Silver □ Zinc □ Nickel □ Nitrate/Nitrite □ Selenium □ Silver
3. While your lead levels do not exceed federal or state standards, the North Carolina Division of Public Health has concerns with any detection of lead. Should you have any questions please contact the NC Private Well and Health Program at (919) 707 - 5900.
4. Re-sample for lead and /or copper. Take a first draw and 30-second flush sample inside the house (preferably the
kitchen sink) and a first draw and 4 minutes flush sample at the wellhead to determine the source of the lead and/ or copper.
5. The following substance(s) exceeded aesthetic drinking water standards. Your water can be used for drinking, cooking, washing, cleaning, bathing, and showering based on the <i>inorganic chemical results only</i> , but aesthetic problems such as bad taste, odor, staining of porcelain, etc. may occur. You may want to install a household water treatment system to address aesthetic problems. Chloride Copper Flouride Iron Manganese Manganese Copper Copper
□Chloride □Copper □Flouride □Iron □Manganese □pH □Silver □Sulfate □Zinc
6. a. Sodium levels exceed the U.S. Environmental Protection Agency's (USEPA) Health Advisory level for sodium of 20 mg/l. The North Carolina Division of Public Health recommends that only individuals on no or low sodium-restricted diets not use this water for drinking or cooking. It may be used for washing, cleaning, bathing, and showering based on the <i>inorganic chemical results only</i> .
☐b. Your sodium level exceeds 30 mg/L and may pose aesthetic issues such as bad taste, odor, staining of porcelain, etc.
7. Re-sampling is recommended inmonths, to reinvestigate