



Permit Inspections Harnett County

Permit Number: **SFD2203-0071**

Description: **50.9x47.8**

Applied: **3/15/2022**

Approved: **9/9/2022**

Site Address: **1390 COOL SPRINGS RD**

Issued: **9/13/2022**

Finalized:

City, State Zip Code: **LILLINGTON, NC 27546**

Status: **ISSUED**

Applicant: **LAMCO CUSTOM BUILDERS LLC**

Parent Permit:

Owner: **LAMCO CUSTOM BUILDERS LLC**

Parent Project:

Contractor: **LAMCO CUSTOM BUILDERS LLC**

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			ADDRESS	GIS Bucket		
Notes:						
			GAS PIPING	Steven Gazlay		
Notes:						
	9/15/2022	9/15/2022	FOOTING	Steven Gazlay	APPROVED	eTRAKiT Inspection Request
Notes: 9/13/2022 2:23 PM LAMCO CUSTOM BUILDERS LLC Contact Name: LAMCO CUSTOM BUILDERS LLC Site Address: 1390 COOL SPRINGS RD Phone: 9193074254 e-Mail: accounting@lamcohomes.com						
	9/28/2022	9/28/2022	T-POLE	James T Hall	CANCELLED	eTRAKiT Inspection Request
Notes: 9/26/2022 3:41 PM LAMCO CUSTOM BUILDERS LLC Contact Name: LAMCO CUSTOM BUILDERS LLC Site Address: 1390 COOL SPRINGS RD Phone: 9198594190 e-Mail: Lamcoacctdept@gmail.com						
	9/28/2022	9/28/2022	FOUNDATION	James T Hall	APPROVED	eTRAKiT Inspection Request
Notes: 9/26/2022 3:40 PM LAMCO CUSTOM BUILDERS LLC Contact Name: LAMCO CUSTOM BUILDERS LLC Site Address: 1390 COOL SPRINGS RD Phone: 9198594190 e-Mail: Lamcoacctdept@gmail.com						





Permit Inspections Harnett County

	10/14/2022	10/14/2022	T-POLE	James T Hall	APPROVED	eTRAKIT Inspection Request
--	------------	------------	--------	--------------	----------	----------------------------

Notes:

	10/14/2022	10/14/2022	WATER CONNECTION	James T Hall	APPROVED	eTRAKIT Inspection Request
--	------------	------------	------------------	--------------	----------	----------------------------

Notes:
 10/11/2022 8:24 AM LAMCO CUSTOM BUILDERS LLC

 Contact Name: LAMCO CUSTOM BUILDERS LLC
 Site Address: 1390 COOL SPRINGS RD
 Phone: 9198594190
 e-Mail: Lamcoacctdept@gmail.com

	10/14/2022	10/14/2022	UNDER SLAB TRADES	James T Hall	APPROVED	eTRAKIT Inspection Request
--	------------	------------	-------------------	--------------	----------	----------------------------

Notes:
 10/10/2022 9:13 AM LAMCO CUSTOM BUILDERS LLC

 Contact Name: LAMCO CUSTOM BUILDERS LLC
 Site Address: 1390 COOL SPRINGS RD
 Phone: 9198594190
 e-Mail: Lamcoacctdept@gmail.com

	10/14/2022	10/14/2022	SEWER CONNECTION	James T Hall	APPROVED	eTRAKIT Inspection Request
--	------------	------------	------------------	--------------	----------	----------------------------

Notes:
 10/11/2022 8:24 AM LAMCO CUSTOM BUILDERS LLC

 Contact Name: LAMCO CUSTOM BUILDERS LLC
 Site Address: 1390 COOL SPRINGS RD
 Phone: 9198594190
 e-Mail: Lamcoacctdept@gmail.com

	10/20/2022	10/20/2022	SLAB	John B Kokoszka	APPROVED	eTRAKIT Inspection Request
--	------------	------------	------	-----------------	----------	----------------------------

Notes:
 10/17/2022 1:58 PM LAMCO CUSTOM BUILDERS LLC

 Contact Name: LAMCO CUSTOM BUILDERS LLC
 Site Address: 1390 COOL SPRINGS RD
 Phone: 9198594190
 e-Mail: Lamcoacctdept@gmail.com

There was 2 sets on slab drawings on site. I used the drawings that where stamped from harnett county. Those plans didn't has a lug footing by the garage.





Permit Inspections Harnett County

	12/2/2022	12/2/2022	INSULATION	Deen Taylor	DISAPPROVED	eTRAKiT Inspection Request
--	-----------	-----------	------------	-------------	-------------	----------------------------

Notes:

11/29/2022 7:01 AM LAMCO CUSTOM BUILDERS LLC

Contact Name: LAMCO CUSTOM BUILDERS LLC
 Site Address: 1390 COOL SPRINGS RD
 Phone: 9198594190
 e-Mail: Lamcoacctdept@gmail.com

11/30/2022 2:50 PM LAMCO CUSTOM BUILDERS LLC

Contact Name: LAMCO CUSTOM BUILDERS LLC
 Site Address: 1390 COOL SPRINGS RD
 Phone: 9198594190
 e-Mail: Lamcoacctdept@gmail.com

Waterlines for water heater in garage must be insulated or on heated side of insulation

	12/6/2022	12/6/2022	INSULATION REINSPECTION	Steven Gazlay	APPROVED	eTRAKiT Inspection Request
--	-----------	-----------	-------------------------	---------------	----------	----------------------------

Notes:

12/2/2022 1:54 PM LAMCO CUSTOM BUILDERS LLC

Contact Name: LAMCO CUSTOM BUILDERS LLC
 Site Address: 1390 COOL SPRINGS RD
 Phone: 9198594190
 e-Mail: Lamcoacctdept@gmail.com

	2/6/2023	2/6/2023	TEMP POWER CERTIFICATION	James T Hall	APPROVED	eTRAKiT Inspection Request
--	----------	----------	--------------------------	--------------	----------	----------------------------

Notes:

2/3/2023 7:47 AM LAMCO CUSTOM BUILDERS LLC

Contact Name: LAMCO CUSTOM BUILDERS LLC
 Site Address: 1390 COOL SPRINGS RD
 Phone: 9198594190
 e-Mail: Lamcoacctdept@gmail.com

20	9/23/2022	9/23/2022	FOUNDATION SURVEY	CP Bucket	APPROVED	eTRAKiT Inspection Request
----	-----------	-----------	-------------------	-----------	----------	----------------------------

Notes:

9/23/2022 2:40 PM LAMCO CUSTOM BUILDERS LLC
 foundation survey uploaded

Contact Name: LAMCO CUSTOM BUILDERS LLC
 Site Address: 1390 COOL SPRINGS RD
 Phone: 9198594190
 e-Mail: Lamcoacctdept@gmail.com





Permit Inspections Harnett County

30		11/23/2022	ROUGH IN	Steven Gazlay	DISAPPROVED	eTRAKIT Inspection Request
<p>Notes:</p> <p>11/18/2022 3:27 PM LAMCO CUSTOM BUILDERS LLC</p> <p>Contact Name: LAMCO CUSTOM BUILDERS LLC Site Address: 1390 COOL SPRINGS RD Phone: 9198594190 e-Mail: Lamcoacctdept@gmail.com</p> <p>Seal top of furred wall in garage and bath. Toilet flanges missing anchors. Missing some air barrier at stairs. Ok to side and insulate.</p>						
30	12/2/2022	12/2/2022	ROUGH IN REINSPECT	Deen Taylor	APPROVED	eTRAKIT Inspection Request
<p>Notes:</p> <p>11/29/2022 7:00 AM LAMCO CUSTOM BUILDERS LLC</p> <p>Contact Name: LAMCO CUSTOM BUILDERS LLC Site Address: 1390 COOL SPRINGS RD Phone: 9198594190 e-Mail: Lamcoacctdept@gmail.com</p> <p>11/30/2022 2:50 PM LAMCO CUSTOM BUILDERS LLC</p> <p>Contact Name: LAMCO CUSTOM BUILDERS LLC Site Address: 1390 COOL SPRINGS RD Phone: 9198594190 e-Mail: Lamcoacctdept@gmail.com</p>						
40			ENVIR OPERATIONS PERMIT	EH Bucket		
<p>Notes:</p>						
50			FINAL SFD STEMWALL **	Steven Gazlay		
<p>Notes:</p>						

