



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

10/21/2022

**SUBJECT: SFD2203-0078**  
**SINGLE FAMILY DWELLING**

To: Angela Lyon

Here are the results of all Inspections located at **1718 PONDEROSA RD:**

Inspection Type: GAS PIPING  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Steven Gazlay  
Result:  
Remarks:  
Notes:

Inspection Type: INSULATION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Steven Gazlay  
Result:  
Remarks:  
Notes:

Inspection Type: SEWER CONNECTION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Steven Gazlay  
Result:  
Remarks:  
Notes:

Inspection Type: TEMP POWER CERTIFICATION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Steven Gazlay  
Result:  
Remarks:  
Notes:



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: WATER CONNECTION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Steven Gazlay  
Result:  
Remarks:  
Notes:

Inspection Type: FOUNDATION SURVEY  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: CP Bucket  
Result:  
Remarks: not needed  
Notes:

Inspection Type: ENVIR OPERATIONS PERMIT  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: EH Bucket  
Result:  
Remarks:  
Notes:

Inspection Type: FINAL SFD CRAWL\*\*  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Steven Gazlay  
Result:  
Remarks:  
Notes:

Inspection Type: ROUGH IN REINSPECT  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Steven Gazlay  
Result:  
Remarks: eTRAKiT Inspection Request  
Notes:



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: T-POLE  
Scheduled Date/Time: 7/8/2022  
Completed Date/Time: 7/8/2022  
Inspector: Steven Gazlay  
Result: APPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 7/7/2022 9:56 AM Angie Lyon

Contact Name: Angie Lyon  
Site Address: 1718 PONDEROSA RD  
Phone: 9193530276  
e-Mail: angielyon1974@gmail.com

Inspection Type: FOOTING  
Scheduled Date/Time: 7/8/2022  
Completed Date/Time: 7/8/2022  
Inspector: Steven Gazlay  
Result: APPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 7/7/2022 9:56 AM Angie Lyon

Contact Name: Angie Lyon  
Site Address: 1718 PONDEROSA RD  
Phone: 9193530276  
e-Mail: angielyon1974@gmail.com

Inspection Type: OPEN FLOOR  
Scheduled Date/Time: 8/1/2022  
Completed Date/Time: 8/1/2022  
Inspector: James T Hall  
Result: CANCELLED  
Remarks:  
Notes: foundation has not been done.

Inspection Type: FOUNDATION  
Scheduled Date/Time: 8/4/2022  
Completed Date/Time: 8/4/2022  
Inspector: Steven Gazlay  
Result: APPROVED  
Remarks:  
Notes:





**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: OPEN FLOOR  
Scheduled Date/Time: 8/4/2022  
Completed Date/Time: 8/4/2022  
Inspector: Steven Gazlay  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: ADDRESS  
Scheduled Date/Time: 10/14/2022  
Completed Date/Time: 10/18/2022  
Inspector: GIS Bucket  
Result: APPROVED  
Remarks:  
Notes: 1718 PONDEROSA RD  
28326

Inspection Type: ROUGH IN  
Scheduled Date/Time: 10/18/2022  
Completed Date/Time: 10/18/2022  
Inspector: Steven Gazlay  
Result: DISAPPROVED  
Remarks:  
Notes: No plumbing tests. Shower pan liner not installed. Seal top of furred laundry wall. Bath fans not connected. Missing nail plates on 3" pvc stack. Seal chases. Bolt 4 ply truss per mfg. missing insulation baffles. Do not insulate.

Inspection Type: ROUGH IN REINSPECT  
Scheduled Date/Time: 10/21/2022  
Completed Date/Time: 10/21/2022  
Inspector: Steven Gazlay  
Result: DISAPPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 10/18/2022 3:04 PM Angie Lyon

Contact Name: Angie Lyon  
Site Address: 1718 PONDEROSA RD  
Phone: 9193530276  
e-Mail: angielyon1974@gmail.com

Frame and seal top of chase/closet of upstairs air handler. Install baffles in laundry room ceiling. Ok to insulate.