

# Harnett County Department of Public Health Improvement Permit

A building permit cannot be issued with only an Improvement Permit

121 Western Pine Way

ISSUED TO: Adams Homes AEC LLC PROPERTY LOCATION: SR 1209 Barbours Church RD SUBDIVISION: Canaan Woods LOT # 23

NEW  REPAIR  EXPANSION  Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: 49'x54' SFD

Proposed Wastewater System Type: Pump to 25% reduction

Projected Daily Flow: 480 GPD

Number of bedrooms: 4 Number of Occupants: 4 max

Basement  Yes  No

Pump Required:  Yes  No  May be required based on final location and elevations of facilities

Type of Water Supply:  Community  Public  Well Distance from well \_\_\_\_\_ feet

Permit valid for:  Five years  No expiration

Permit conditions: \_\_\_\_\_

Authorized State Agent: Mah RETH Date: 9-21-22 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

## Construction Authorization (Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

121 Western Pine Way

ISSUED TO: Adams Homes AEC LLC PROPERTY LOCATION: SR 1209 Barbours Church RD SUBDIVISION: Canaan Woods LOT # 23

Facility Type: 49'x54' SFD  New  Expansion  Repair

Basement?  Yes  No Basement Fixtures?  Yes  No

Type of Wastewater System\*\* Pump to 25% reduction (Initial) Wastewater Flow: 480 GPD

(See note below, if applicable  Pump to 25% reduction (Repair))

Installation Requirements/Conditions

Septic Tank Size <u>1000</u> gallons	Number of trenches <u>1</u>	Exact length of each trench <u>300</u> feet	Trench Spacing: <u>9</u> Feet on Center
Pump Tank Size <u>1000</u> gallons	Trenches shall be installed on contour at a	Maximum Trench Depth of: <u>14-16</u> inches	Soil Cover: <u>6</u> inches
	(Trench bottoms shall be level to +1-1/4" in all directions)	(Maximum soil cover shall not exceed 36" above the trench bottom)	

Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM

Aggregate Depth: 6 inches below pipe  
2 inches above pipe  
12 inches total

Conditions: MUST bring in 2"-4" of Group II or Group III Soil to Cover Drain Field

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.  
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: Mah RETH Date: 9-21-22

Construction Authorization Expiration Date: 9-21-27

Application # SFD2203-0083

## Harnett County Department of Public Health Site Sketch

Property Location: 121 Western Pine Way (SR 1209)

Issued To: Adams Homes

Subdivision Cameron Woods


Lot # 23

Authorized State Agent: *Mohammed REHS*

Date: 09-21-22

Will need 2"-4" of cover  
brought in for Drain field

Bring supply line from  
pump tank to DBOX,  
keeping supply line 5 foot  
from property line and  
set DBOX 10 foot  
from property line



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.