


- \*Keep tanks and drain lines 10' from property lines.
- \*Not a survey.
- \*Not a guarantee of a septic permit.
- \*Keep supply lines >5' from property lines.
- \*Some lines are flagged longer in the field than lengths indicate.
- \*No grading septic area.

System: Pump to D-Box Lines: 1-4, (4x67'x3') EZ Flow 0.4 Soil LTAR 24" Trench Bottom
Repair: Pressure Manifold Lines: 5-9, (245') T&J Panel 0.4 Soil LTAR 24" Trench Bottom



Central Carolina Soil Consulting, PLLC  
 1900 South Main Street, Suite 110  
 Wake Forest, North Carolina 27587  
 Phone (919)569-6704 Fax (919)569-6703

3-Bedroom Septic Layout  
 Lot 114, Birchwood Subdivision  
 Wake County, North Carolina

Job# : 3753
Drawn By : LW
Date : 08/17/2021
Revision: