

May 2, 2022

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Weaver Homes, Inc.
350 Wagoner Drive
Fayetteville, NC 28303

ph: 910-893-7547
fax: 910-893-9371

Re: Status of Improvement Permit Application: SFD2203-0113

To whom it may concern:

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible. (*\$25.00 fee incurred*)
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. Other- Unapproved plot plan. As consistent with original soil development map, Suitable soil only present on front portion of property. House box shall be shifted back to 100ft front setback, side entry garage, and driveway/utilities along property lines. 3-Bedroom Max. Revise paperwork accordingly and reconfirm when remarked by surveyor.**

Your application will be put on hold until the selected items above have been addressed.

When completed, **please call Central Permitting at 910-893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns please call 910-893-7547.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc

Copy: Central Permitting

strong roots • new growth