

May 2, 2022

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Weaver Homes, Inc.
350 Wagoner Drive
Fayetteville, NC 28303

ph: 910-893-7547
fax: 910-893-9371

Re: Status of Improvement Permit Application: SFD2203-0118

To whom it may concern:

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible. (*\$25.00 fee incurred*)
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. Other- Limited available space. 3-Bedroom Max. Rear yard shall be clear back to evaluate for additional septic field in rear. Heavy over brush present along wood line. Alternate option: House box shall be shifted back to 100ft front setback, side entry garage, and driveway/utilities along property lines. Revise paperwork accordingly and reconfirm when remarked by surveyor.**

Your application will be put on hold until the selected items above have been addressed.

When completed, **please call Central Permitting at 910-893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns please call 910-893-7547.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc

Copy: Central Permitting

strong roots • new growth