



ECS Southeast, LLP

6151 Raeford Road, Suite A
Fayetteville, NC 28304
9104013288
9103230539

LETTER OF TRANSMITTAL

March 9, 2023
Homeowner Cook

Four Oaks, NC 27528
ATTN: Timothy Cook

RE: **Timothy Cook**
ECS Job # **33:6289**

Permits:
Location: **291 Pendergraft St**
Bunnlevel, NC 28323

Field Reports For your use As requested

CC:

ENCL: Field Report # 1 3/9/2023



MAR 09 2023

Jack Cowser, P.E.
Office Manager

Aaron Kyle Adair
Team Leader

Disclaimer

1. This report (and any attachments) shall not be reproduced except in full without prior written approval of ECS.
2. The information in this report relates only to the activities performed on the report date.
3. Where appropriate, this report includes statements as to compliance with applicable project drawings, and specifications for the activities, performed on this report date.
4. Incomplete or non-conforming work will be reported for future resolution.
5. The results of samples and/or specimens obtained or prepared for subsequent laboratory testing will be presented in separate reports/documents.



ECS Southeast, LLP
 6151 Raeford Road, Suite A
 Fayetteville, NC 28304
 (910) 401-3288 [Phone]
 (910) 323-0539 [Fax]

FIELD REPORT

Project **Timothy Cook**
 Location **Bunnlevel, NC**
 Client **Homeowner Cook**
 Contractor **None Listed**

Project No. **33:6289**
 Report No. **1**
 Day & Date **Thursday 3/9/2023**
 Weather **52 °/ Sunny**
 On-Site Time **2.75**
 Lab Time **0.00**
 Travel Time* **0.00**
 Total **2.75**
 Re Obs Time **0.00**

Remarks	Tolls/Parking*	Mileage*	Time of Arrival	Departure
Trip Charges* Chargeable Items			10:00A	12:45P

* Travel time and mileage will be billed in accordance with the contract.

Summary of Services Performed (field test data, locations, elevations & depths are estimates) & Individuals Contacted.

An ECS representative arrived on site, as requested, to check the bearing capacity of soils via hand auger/DCP method for foundation footings. Please see the attached sketch for location details.

A total of 4 hand auger/DCP evaluations were performed to a depth of approximately 24" feet below the current sub grade elevation. ECS encountered auger refusal at all locations at various depths due to stone/pebbles. Test results indicated that the materials in place (at the locations and elevations tested) did appear to be suitable to support the design bearing capacity 1,500 psf.

ECS will return, as requested, to perform additional services.