

# Harnett County Department of Public Health

## Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Weaver Homes Inc. PROPERTY LOCATION: 203 Mitchell Manor Dr. (Mitchell Rd. - 1535  
 SUBDIVISION Mitchell Manor PH II LOT # 6

NEW  REPAIR  EXPANSION  Site Improvements required prior to Construction Authorization Issuance: \_\_\_\_\_

Type of Structure: 53'x52' (3bed/3ba) sfd

Proposed Wastewater System Type: 25% Reduction Sys.

Projected Daily Flow: 360 GPD


Number of bedrooms: 3 Number of Occupants: 6 max

Basement  Yes  No

Pump Required:  Yes  No  May be required based on final location and elevations of facilities

Type of Water Supply:  Community  Public  Well Distance from well NA feet Permit valid for:  Five years  
 No expiration

Permit conditions: \_\_\_\_\_

Authorized State Agent:  Date: 05/25/2022 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

## Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Weaver Homes Inc. PROPERTY LOCATION: 203 Mitchell Manor Dr. (Mitchell Rd. - 15  
 SUBDIVISION Mitchell Manor PH II LOT # 6

Facility Type: 53'x52' (3bed/3ba) sfd  New  Expansion  Repair

Basement?  Yes  No Basement Fixtures?  Yes  No

Type of Wastewater System\*\* Pump to At- Grade 25% Reduction System (Initial) Wastewater Flow: 360 GPD

(See note below, if applicable ) 50% Reduction PPBPS Sys. (Repair)

Installation Requirements/Conditions

Septic Tank Size <u>1000</u> gallons	Number of trenches <u>4</u>	Exact length of each trench <u>60</u> feet	Trench Spacing: <u>9</u> Feet on Center
Pump Tank Size <u>1000</u> gallons	Trenches shall be installed on contour at a	Maximum Trench Depth of: <u>12-14</u> inches	Soil Cover: <u>Import 6</u> inches
	(Trench bottoms shall be level to +/-1/4"	in all directions)	(Maximum soil cover shall not exceed 36" above the trench bottom)

Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM

Aggregate Depth: NA inches below pipe  
NA inches above pipe  
NA inches total

Conditions: Pump to Medium D-Box Equal Distribution Required

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.**  
**NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent:  Date: 05/25/2022  
ANDREW CORBIN Construction Authorization Expiration Date: 05/25/2027

# Harnett County Department of Public Health Site Sketch

Property Location: 203 Mitchell Manor Dr. (Mitchell Rd. - 1535)

Issued To: Weaver Homes Inc. Subdivision Mitchell Manor PH II Lot # 6

Authorized State Agent: ANDREW CORBIN Date: 05/25/2022

### GENERAL CONTRACTOR

- \* UTILITIES [WATER/POWER] SHALL BE ROUTED UNDER OR TO LEFT OF DRIVEWAY
- \* ADVISED TO HAVE BILL MARK UTILITIES AT ROAD DUE TO PROXIMITY

### INSTALLER

- \* PUMP TO MEDIUM D-BOX EQUAL DISTRIBUTION REQUIRED W/ STOPDOWN ON LAST LINE [NO SERIAL]
- \* MAINTAIN CLEARANCE OF SLAB OVERCUT @ HOUSIE
- \* 6IN IMPORT L-1 SOIL COVER SHELL MANOR 5in



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.