

April 25, 2022

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Cumberland Homes Inc.
PO Box 727
Dunn, NC 28334

ph: 910-893-7547
fax: 910-893-9371

Re: Status of Improvement Permit Application: SFD2204-0015

To whom it may concern:

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible. (*\$25.00 fee incurred*)
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. **Other- Incorrect Property Lines – Right property line incorrectly marked onsite. Right line flagged with wrong rear iron. No back property line marked onsite. Due to lot size and topography, traditional septic permit cannot be guaranteed. Panel block system, large diameter pipe, or pump may be required and/or septic proposal may be required.**

Your application will be put on hold until the selected items above have been addressed.

When completed, **please call Central Permitting at 910-893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns please call 910-893-7547.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc
Copy: Central Permitting