

May 2, 2022

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Stephen Ragan
8405 Falcon Crest Circle
Angier, NC 27501

ph: 910-893-7547
fax: 910-893-9371

Re: Status of Improvement Permit Application: SFD2204-0037

Mr. Ragan:

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible. (*\$25.00 fee incurred*)
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. Other- Revise Site Plan. House flagged onsite further off front easement then shown on site plan. Due to drainage cut in rear, house shall be shifted back to minimum 60ft front setback to allow for front yard septic area. Secondly, driveway shall be shifted to right property line to maximize front septic area. Revise site plan, remark home onsite, and reconfirm when ready.**

Lot advised to be cleared without disturbing soil prior to reconfirming.

Your application will be put on hold until the selected items above have been addressed. When completed, **please call Central Permitting at 910-893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns please call 910-893-7547.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc

Copy: Central Permitting

strong roots • new growth