

September 19<sup>th</sup>, 2024

Family Building Company II LLC  
1016 Mockingbird Drive  
Raleigh, NC 27615

**Re: Status of Permit Application-SFD2204-0037**

**To whom it may concern,**

An attempt was made to evaluate your property for issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

  1. Use pink flags to mark left property lines, survey irons to be located and demonstrated. Property lines marked/flagged every 50'. (25.00 Fee Incurred)

  2. House Box needs to be accurately and marked/demonstrated. (25.00 Fee Incurred)

  3. Directions not clear to property (*\$25.00 fee incurred*)

  4. Property needs undergrowth cleared, vegetation must be cleared (brushes, limbs, briars) in area behind house box to determine the change in soil and available septic room for the initial and repair area.

  5. Driveway not shown on site plan

  6. Backhoe Pits Required-

  **X 7. Other – House box needs to be moved at least 80' or more from front property line. Driveway needs to be demonstrated (onsite) and updated on site plan showing the driveway hugging against right property line to allow space for septic system in front yard.**

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7525 ext. 2 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Reynold Levocz R.E.H.S.  
Environmental Health Specialist  
Harnett County Department of Public Health

RL/kh  
Copy: Central Permitting