

Jerome Rufaro Redmond, PE
Building Engineering & Design
Building Analysis
Structural Design
Project Management

8209A Market St. Ste 222 Wilmington, NC 28411
P: 910.915.6529 E: jrednc5@yahoo.com

April 26, 2023

MEMO

RE: 2165 Cane Mills Road - Coats, NC
Project No: IN022412

The 11 7/8" NI 80 I joists have higher structural properties than the LP36 I joist specified and are therefore an acceptable for use.

Please give me a call if you have any further questions.

Regards,



Jerome Rufaro Redmond, PE
Principal Structural Engineer