

May 22, 2023



Mr. Austin Brown
Starlight Homes
5711 Six Forks Road, Suite #200
Raleigh, North Carolina 27609

**Subject: Summary of Front Porch Fill Evaluation
Lot No. 66 – (259 Timber Skip Drive)
Anderson Creek Crossing Subdivision
Spring Lake, North Carolina
Permit Number: N/A
Project Number: 6033.500 (37213-01)**


Dear Mr. Brown:

On May 12, 2023, a representative of SUMMIT Engineering, Laboratory and Testing, Inc. (SUMMIT) visited the subject site for the purpose of observing and evaluating the front porch fill material. The following is a summary of our onsite observations and evaluation.

The front porch area was backfilled with washed stone (NCDOT No. 57 stone) prior to our site visit. The front porch was evaluated by hand probing using a ½ inch diameter steel probe rod to check for loose areas at the surface. Based on hand probing and our site observations, the materials encountered are suitable for support of the proposed residential slab loading conditions.

SUMMIT appreciates the opportunity to assist you during this phase of the project. If you need further assistance or additional information please do not hesitate to contact us.

Sincerely,
SUMMIT Engineering, Laboratory and Testing, Inc.



Jeff A. Taylor, P.E.
Geotechnical Engineer

A handwritten signature in black ink, appearing to read "Adam D. Perry".

Adam D. Perry, E.I.
Staff Professional