## Harnett County Department of Public Health

## Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 1214 SHERIFF JOHNSON RD (SR 1516) ISSUED TO: SERENITY BUILT HOMES INC SUBDIVISION TLM PROPERTIES OF NC LLC REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance: Type of Structure: 3-BEDROOM 49' x 59' SFD Proposed Wastewater System Type: 25% REDUCTION SYS Projected Daily Flow: 360 Number of bedrooms: 3 Number of Occupants: 6 Basement Yes May be required based on final location and elevations of facilities ☐ No Pump Required: Yes Type of Water Supply: Community Public Well Distance from well NA feet X Five years Permit valid for: No expiration Permit conditions: 06/04/2022 Authorized State Agent:: The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: SERENITY BUILT HOMES INC PROPERTY LOCATION: 1214 SHERIFF JOHNSON RD (SR 151) SUBDIVISION TLM PROPERTIES OF NC LLC LOT # 2 Facility Type: 3-BEDROOM 49' x 59' SF Expansion X No Basement Fixtures? Yes Basement? Yes Type of Wastewater System\*\* 25% REDUCTION SYSTEM (Initial) Wastewater Flow: 360 GPD (See note below, if applicable ) 25% REDUCTION SYSTEM Number of trenches 2 Installation Requirements/Conditions Exact length of each trench 120 Septic Tank Size (OOO gallons Pump Tank Size \_\_\_\_\_ Trenches shall be installed on contour at a Maximum Trench Depth of: 26 (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: ft. TDH vs. \_ inches below pipe inches above pipe inches total Conditions: WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: Date: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Construction Authorization Expiration Date: 06/64/2027

Authorized State Agent:

ANDREW CURIN

## Harnett County Department of Public Health Site Sketch

Property Location: 1214 SHERIFF JOHNSO	ON RD (SR 1516)	
Issued To: SERENITY BUILT HOMES INC	Subdivision TLM PROPERTIES OF NC LLC	Lot # 2
Authorized State Agent:	ANSTEN CONIN	: 06/07/2022
202	127"E 143.14'	
1	15 25 MBS	
	Proposed of Proposed	, × 30,
188   E	1 2   200°   200	, S
Wap #2022	5 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 -	1
of si to	78W 143.14	
	N 20 27 21	

This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.