
## Harnett County Department of Public Health

## Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 141 TYREE CO. (FESTUS 60). - 5-C1560) ISSUED TO: ERIC BLUE SUBDIVISION TEE TOP REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance: Type of Structure: 3-BEDZCOM 44 X46' STD 25% - TOURTION STS. Proposed Wastewater System Type: \_\_ GPD Projected Daily Flow: 600 Number of Occupants: \_\_ / <> \_\_ max Number of bedrooms: Basement Yes No Pump Required: Yes May be required based on final location and elevations of facilities Type of Water Supply: Community Public Well Distance from well 6et Five years Permit valid for: -No expiration Permit conditions: 07/26/2022 SEE ATTACHED SITE SKETCH The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. PROPERTY LOCATION: 141 THATE LIS. (FZSTUS TO - SCISCO) ISSUED TO: EALC BLUTZ Facility Type: 5-BEDICON 44'x4C' SED New Repair Expansion Basement? Yes No Basement Fixtures? Yes Type of Wastewater System\*\* 25% resoction STOTEL (Initial) Wastewater Flow: 600 (See note below, if applicable ) 25% NEOSCHION SYSTEM Number of trenches 4 Installation Requirements/Conditions Exact length of each trench 100 Trench Spacing: Septic Tank Size 1250 gallons Soil Cover: Trenches shall be installed on contour at a Pump Tank Size gallons Maximum Trench Depth of: 18 (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: \_\_\_\_\_\_ft. TDH vs. \_\_ \_ inches below pipe inches above pipe Aggregate Depth: Conditions: GRAVITY TO D-BOX EGNAL DISTURSTION REGULATO inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Date: Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Authorized State Agent: Construction Authorization Expiration Date: 67/26/2027 ANDREW CORRIN

## Harnett County Department of Public Health Site Sketch



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.