



HANGER LEGEND	
	= USP THF25140 / Single I-Joist Hanger

Beam Legend					
PlotID	Length	Product	Plies	Net Qty	Fab Type
BM4	11' 0"	1-3/4"x 9-1/4" LVL Kerto-S	2	4	FF
BM3	7' 0"	1-3/4"x 9-1/4" LVL Kerto-S	2	4	FF
BM2	6' 0"	1-3/4"x 9-1/4" LVL Kerto-S	2	2	FF
GDH	22' 0"	1-3/4"x 11-7/8" LVL Kerto-S	3	3	FF
BM1	20' 0"	1-3/4"x 18" LVL Kerto-S	3	3	FF

I-Joist Legend					
PlotID	Length	Product	Plies	Net Qty	Fab Type
IJ1	39' 8 13/16"	14" NI-40x	1	5	FF
IJ2	28' 3"	14" NI-40x	1	10	FF
IJ3	17' 5 7/16"	14" NI-40x	1	2	FF
IJ4	11' 4 1/2"	14" NI-40x	1	2	FF
IJ5	11' 0 3/4"	14" NI-40x	1	10	FF
IJ6	8' 3"	14" NI-40x	1	1	FF
IJ7	3' 9"	14" NI-40x	1	1	FF
IJ8	3' 5 5/8"	14" NI-40x	1	1	FF
RIM1	12' 0"	1 1/8" x 14" Rim Board	1	14	FF
	2' 11"	Backer Blocks (14" NI-40x)	1	2	Other
	2' 0 3/4"	Backer Blocks (14" NI-40x)	1	2	Other
	1' 3 1/4"	Backer Blocks (14" NI-40x)	1	2	Other
	1' 2 1/2"	Backer Blocks (14" NI-40x)	1	2	Other
	1' 0 3/4"	Backer Blocks (14" NI-40x)	1	2	Other
	1' 0"	Backer Blocks (14" NI-40x)	1	12	Other
		Web Stiffeners (14" NI-40x)	1	51	Other

**Truss Placement Plan**  
SCALE: 1/4" = 1'

LOAD CHART FOR JACK STUDS		
(BASED ON TABLES R502.5(1) & (2))		
NUMBER OF JACK STUDS REQUIRED @ EA END OF HEADS/GIRDER		
END REACTION (UP TO) 1700	END REACTION (UP TO) 2550	END REACTION (UP TO) 3400
1	1	1
3400	5100	6800
2	2	2
5100	7650	10200
3	3	3
6800	10200	13600
4	4	4
8500	12750	17000
5	5	5
10200	15300	
6		
11900		
7		
13600		
8		
15300		
9		

<b>BUILDER</b>	Cates Building, Inc.	<b>CITY / CO.</b>	Cameron / Harnett
<b>JOB NAME</b>	Lot 674 Lexington Plantation	<b>ADDRESS</b>	98 Bow Common Way
<b>PLAN</b>	CC-2560 / 2ND FLOOR I-JOIST	<b>MODEL</b>	31500
<b>SEAL DATE</b>	2/1/21	<b>DATE REV.</b>	04/20/22
<b>QUOTE #</b>	B1020-4961	<b>DRAWN BY</b>	Curtis Quick
<b>JOB #</b>	J0322-1510	<b>SALES REP.</b>	Scot Duncan

**THIS IS A TRUSS PLACEMENT DIAGRAM ONLY.**  
These trusses are designed as individual building components to be incorporated into the building design at the specification of the building designer. See individual design sheets for each truss design identified on the placement drawing. The building designer is responsible for temporary and permanent bracing of the roof and floor system and for the overall structure. The design of the truss support structure including headers, beams, walls, and columns is the responsibility of the building designer. For general guidance regarding bracing, consult BCSI-B1 and BCSI-B3 provided with the truss delivery package or online @ sbcindustry.com

Bearing reactions less than or equal to 3000# are deemed to comply with the prescriptive Code requirements. The contractor shall refer to the attached Tables (derived from the prescriptive Code requirements) to determine the minimum foundation size and number of wood studs required to support reactions greater than 3000# but not greater than 15000#. A registered design professional shall be retained to design the support system for any reaction that exceeds those specified in the attached Tables. A registered design professional shall be retained to design the support system for all reactions that exceed 15000#.

Signature: Curtis Quick  
Curtis Quick

**ROOF & FLOOR TRUSSES & BEAMS**

Reilly Road Industrial Park  
Fayetteville, N.C. 28309  
Phone: (910) 864-8787  
Fax: (910) 864-4444