



July 27, 2022

Ken Dawson
Ken Dawson Homes, Inc.
2493 NC Hwy 242 North
Benson, NC 27504
Email: kenndawson@hotmail.com

Reference: Engineering Services
65 Remington Hills Drive
Bunnlevel, NC 28323
TE&D Project No.: 2201-020659

To Whom It May Concern;

As requested by the client, a representative of Tyndall Engineering & Design, PA (TE&D) made a site visit to observe the following item(s):

- 1) Footing projection observations at the piers of the foundation.

The following conclusions/recommendations were made:


- 1) The existing footing projection at the foundation piers were visually observed with regard to compliance with the project plans. Our inspection consisted of spot checking the projection with a probe rod. Based on our visual observations and analysis, the existing flush piers had suitable projection at all faces. The footing projection of the flush piers will provide the required support for the anticipated loading conditions.

We appreciate being able to assist you during this phase of the project. If you need further assistance or require additional information, please do not hesitate to contact us.

Sincerely,
Tyndall Engineering & Design

Tripp Amos
PT III | 2201-020659

Prentice Tyndall Jr., P.E.





Piers inspected