



# AA TAKLA ENGINEERING, PLLC Consulting. Design. Efficiency.

Atef A. Takla, PE | 919-358-1758 | ateftakla@taklaengr.com

NC Firm License No. P-1446  
418 Vivaldi Dr. Durham, NC 27712

Project: Lot # 4 Purfoy  
Location: Fuquay-varina  
Date: 8/27/24  
Company: GemHomes  
Care Of: Daniel Hager  
(984)296-4989



AS REQUESTED A. TAKLA OBSERVED THE  
Following Items :-

- (A) Attachments of (2)-2x8" Header  
to "LVL" valleys. Are adequate  
to support ceiling joists in Bonus  
Room.
- (B) in-place clips "L70" for rafters  
2x6" attachment to "LVL" valleys  
and (2)-2x8 Header Are adequate.

Limitations of Inspection: Services provided are in accordance with the standard of practice for structural engineering and within the limits imposed by scope, schedule and budget. The determinations contained in this report are based on conditions observed at the time of the evaluation. No guarantees or warranties, expressed or implied, under this Agreement or otherwise, shall be construed in connection with services provided. Sequencing, shoring, means and methods of construction are considered beyond the scope of this report.