

June 28, 2023

Austin Robertson Halcyon Homes arobertson@halcyonhomesnc.com

Re:

Foundation Inspection

28 Prince Place

Harnett County, North Carolina

GeoTechnologies Project No. 1-23-0599-EA

## Gentlemen:

GeoTechnologies, Inc. has completed the authorized foundation inspection for the residential structure under construction on Lot 28 at Prince Place in Harnett County, North Carolina. Third party inspection was conducted and verification of foundation projections, perimeter CMU walls including interior CMU columns, anchor bolts and foundation positive and French drains were in accordance with plans as provided on-site.

GeoTechnologies, Inc. appreciates the opportunity to provide you with our services during this phase of the project. Please contact us if you should have questions regarding this information or if we may be of further assistance.

Sincerely,

GeoTechnologies, Inc.

Conrad E. Harris, P.E.

NC Registration No. 39768

## **DESIGN PROFESSIONAL INSPECTION FORM**

RECORD OF THE INSPECTION OF A **COMPONENT OR ELEMENT** BY A NC LICENSED ARCHITECT OR ENGINEER

**Project Information:** 

Residential Single-Family Project: Y	Commercial Project: N	
Code Enforcement Project No:	Permit No: SFD2206-0054	
Project Name: 28 Prince Place	Owner: Halcyon Homes	
Project Address: 139 Blue Monarch Lane	Suite No:	
Date Inspected: 6/28/2023	Contractor Name:Halcyon Homes	
Component Inspected: Foundation Inspection/Plan		

Responsible Licensed NC Architect or NC Engineer

	Keep enterior and enterior at the angline of			
Name:	Conrad E. Harris, P.E.			
Firm Name:	GeoTechnologies Inc.			
Phone Numbers:	Office: 919 954-1514	Mobile:	919-815-5586	
Email Address:	charris@geotechpa.com			
Mailing Address:	3200 Wellington Ct./Suite 108/Raleigh/NC/27615			

APPLICABLE CODE:	2018 NCRC			
2018 NCBC = 2018 NC Building Code; 2018 NCRC = 2018 NC Residential Code Describe				
Element/Compon	ent/Type of Inspection: *			
Foundation Inspection/Plan (see letter)				

## Attestation/Signature:

By signing below, I certify that the component and/or element of the building as identified on this form has been inspected by me or someone under my direct supervision per subsection (b2) of NC G.S. 153A-352 and is in compliance with the Code or other proposal of the architect or engineer for the project. This inspection is in compliance with all of the requirements of the above referenced

Code. Attach any additional documents if needed.

Les Emi

Licensed Architect or Engineer

## Inspection Department disclaimer:

Upon the receipt of a signed written document as required under subsection (a) of Article 160A-413.5., Code Enforcement shall be discharged and released from any liabilities, duties and responsibilities imposed by this article or in common law from any claim arising out of or attributed to the component or element in the construction of the building for which the signed written document was submitted. Be aware that this inspection will be noted in all inspection records including the Certificate of Occupancy or Certificate of Compliance. This inspection does not address any local ordinances or zoning requirements.

<sup>\*(</sup>subgrade form/letter may also be required)