

Permit Number: SFD2206-0057 Description: 57x57 sfd, 4 beds

Applied: 6/13/2022 Approved: 7/21/2022 Site Address: 320 PRINCE PLACE DR

Issued: **7/21/2022** Finaled: City, State Zip Code: **FUQUAY-VARINA, NC 27526**

Status: ISSUED Applicant: Halcyon Homes, LLC
Parent Permit: Owner: HALCYON HOMES LLC
Parent Project: Contractor: Halcyon Homes, LLC

Details:

LIST OF INSPECTIONS									
SEQ ID	SCHEDULED DATE	COMPLETED DATE	ТҮРЕ	INSPECTOR	RESULT	REMARKS			
			OPEN FLOOR	Justin Ryan McLeod		eTRAKiT Inspection Request			
Notes:									
	6/14/2022	6/20/2022	ADDRESS	GIS Bucket	APPROVED				
Notes: 320 PRINCE PLACE FUQUAY VARINA 27526.									
	7/22/2022	7/22/2022	FOOTING	Justin Ryan McLeod	APPROVED				
Notes:									
	8/3/2022	8/3/2022	FOUNDATION	Justin Ryan McLeod	APPROVED	eTRAKiT Inspection Request			
Notes: 7/30/2022 3:03 PM Halcyon Homes, LLC Contact Name: Halcyon Homes, LLC Site Address: 320 PRINCE PLACE DR Phone: 9193375245 e-Mail: arobertson@halcyonhomesnc.com									
	8/5/2022	8/5/2022	T-POLE	Justin Ryan McLeod	APPROVED				
Notes: Already has a meter									



8/18/2022 8/18/2022 OPEN FLOOR Justin Ryan McLeod DISAPPROVED eTRAKIT Inspection Request
--

Notes:

8/11/2022 4:03 PM Halcyon Homes, LLC

Contact Name: Halcyon Homes, LLC Site Address: 320 PRINCE PLACE DR

Phone: 9193375245

e-Mail: arobertson@halcyonhomesnc.com

Missing load blocking at rear wall, the furthest to the right on the plan. Need 3 stud column in pony wall there. Will see at rough, tall crawlspace

10/26/2022 INSULATION Justin Ryan APPROVED eTRAKIT Inspection Request

Notes:

10/20/2022 2:19 PM Halcyon Homes, LLC

Contact Name: Halcyon Homes, LLC Site Address: 320 PRINCE PLACE DR

Phone: 9193375245

e-Mail: arobertson@halcyonhomesnc.com

12/5/2022 WATER Justin Ryan APPROVED eTRAKIT Inspection Request

Notes:

12/1/2022 3:09 PM Halcyon Homes, LLC

Contact Name: Halcyon Homes, LLC Site Address: 320 PRINCE PLACE DR

Phone: 9193375245

e-Mail: arobertson@halcyonhomesnc.com

12/5/2022 SEWER Justin Ryan CONNECTION McLeod DISAPPROVED eTRAKIT Inspection Request

Notes:

12/1/2022 3:08 PM Halcyon Homes, LLC

Contact Name: Halcyon Homes, LLC Site Address: 320 PRINCE PLACE DR

Phone: 9193375245

e-Mail: arobertson@halcyonhomesnc.com

Missing tracer

12/15/2022 TEMP POWER Justin Ryan APPROVED eTRAKIT Inspection Request

Notes:

12/13/2022 11:23 AM Halcyon Homes, LLC

Contact Name: Halcyon Homes, LLC Site Address: 320 PRINCE PLACE DR

Phone: 9193375245

 $e\hbox{-}Mail: aroberts on @halcy on home snc.com$



12/15/2022 12/15/2022 GAS PIPING Justin Ryan McLeod APPROVED eTRAKIT Inspection Request

Notes:

12/13/2022 11:24 AM Halcyon Homes, LLC

Contact Name: Halcyon Homes, LLC Site Address: 320 PRINCE PLACE DR

Phone: 9193375245

e-Mail: arobertson@halcyonhomesnc.com

12/15/2022 SEWER Justin Ryan APPROVED eTRAKIT Inspection Request

Notes:

12/13/2022 11:24 AM Halcyon Homes, LLC

Contact Name: Halcyon Homes, LLC Site Address: 320 PRINCE PLACE DR

Phone: 9193375245

e-Mail: arobertson@halcyonhomesnc.com

0 10/20/2022 10/20/2022 ROUGH IN Justin Ryan McLeod DISAPPROVED eTRAKIT Inspection Request

Notes:

10/17/2022 4:08 PM Halcyon Homes, LLC

Contact Name: Halcyon Homes, LLC Site Address: 320 PRINCE PLACE DR

Phone: 9193375245

e-Mail: arobertson@halcyonhomesnc.com

1. Missing htt4 hold down at portal framing per plan. 2. Missing cs16 strapping at portal framing. 3. Missing hurricane clips on 2 rafters above rear door.

4. 3 stud column upstair right rear bedroom closet area. 5. Plan states knee wall height in bonus to be 4' +-.

0 10/26/2022 10/26/2022 ROUGH IN REINSPECT McLeod APPROVED eTRAKIT Inspection Request

Notes:

10/20/2022 2:19 PM Halcyon Homes, LLC

Contact Name: Halcyon Homes, LLC Site Address: 320 PRINCE PLACE DR

Phone: 9193375245

e-Mail: arobertson@halcyonhomesnc.com

20 10/17/2022 10/17/2022 FOUNDATION SURVEY Donna Johnson APPROVED

Notes:

10/17/2022 10:15 AM Halcyon Homes, LLC

Contact Name: Halcyon Homes, LLC Site Address: 320 PRINCE PLACE DR

Phone: 9193375245

e-Mail: arobertson@halcyonhomesnc.com



40	11/23/2022	11/23/2022	ENVIR OPERATIONS PERMIT	Mark Osborne	APPROVED	
Notes:						
50			FINAL SFD CRAWL**	Justin Ryan McLeod		
Notes:						
50	4/6/2023	4/6/2023	FINAL SFD CRAWL**	Justin Ryan McLeod	DISAPPROVED	

Notes:

Child locks on windows downstairs per code, both upstairs bath fans not working, deck stair stringer more than 7 foot span needs support in middle. The garage sink verify what is on lines and p trap is r6.5 insulation rated.