

# North Carolina 2018 - R402.1.5 Total UA



**Property**  
 Lot 10 Williams Farm South  
 115 Rocking Canal Pl, Erwin 28339

**Organization**  
 Southern Energy Manager  
 Justin Smith

**Inspection Status**  
 Results are projected

**JSJ Builders - Maplewood plan**  
 CZ 4 - HERS  
 Maplewood plan

**Builder**  
 JSJ Builders

This report is based on a proposed design and does not confirm field enforcement of design elements.

## Building UA

Elements	NC Reference	As Designed
Ceilings	34.2	30.6
Above-Grade Walls	158.4	128.8
Windows, Doors and Skylights	94.7	82.0
Slab Floor:	64.6	83.0
Framed Floors	16.8	18.3
Foundation Walls	0.0	0.0
Rim Joists	7.6	6.1
<b>Overall UA (Design must be equal or lower):</b>	<b>376.3</b>	<b>348.8</b>

## Requirements

- 402.1.5 Total UA alternative compliance passes by 7.3%.
- 402.3.2 Average SHGC: 0.21 Max SHGC: 0.30
- R402.4.2.2 Air Leakage Testing Air sealing is 0.29 CFM50 / ft<sup>2</sup> Shell Area. It must not exceed 0.30 CFM50 / ft<sup>2</sup> Shell Area.
- R402.5 Area-weighted average fenestration SHGC
- R402.5 Area-weighted average fenestration U-Factor
- R404.1 Lighting Equipment Efficiency
- Mandatory Checklist Mandatory code requirements that are not checked by Ekotrope must be met.
- R403.3.1 Duct Insulation
- 403.3.3 Duct Testing

**Design exceeds requirements for North Carolina 2018 Prescriptive compliance by 7.3%.**

Name: Justin Smith Signature: Justin Smith  
 Organization: Southern Energy Management Digitally signed: 2/17/22 at 2:37 PM

# Energy Code Inspection Checklist



## Property

JSJ Builders - Maplewood plan  
CZ 4 - HERS  
Maplewood plan

## Organization

Southern Energy Manager  
Justin Smith

## Inspection Status

Results are projected

## Builder

JSJ Builders

## General Building Information

Conditioned Area (sq ft)	1,920
Conditioned Volume (cubic ft)	16,922
Insulated Shell Area (sq ft)	4,742

The building energy model in Ekotrope reflects the building assemblies and energy features listed below. Sometimes energy features will change in the field from what has been modeled. The inspection process should identify any changes and ensure that the home continues to meet the applicable energy code.

## Slab

- Name: slab(781 s.f., 140 ft. exterior perimeter)  
R-0 perimeter insulation, R-0 under slab insulation.

## Framed Floor

- Name: over garage (358 s.f.)  
R-0 continuous insulation, R-19 cavity insulation  
Insulation Grade: I

## Foundation Wall

None Present

## Above Grade Wall

- Name: 1st floor ambient (864 s.f.)  
R-0 continuous insulation, R-19 cavity insulation  
Insulation Grade: II
- Name: 1st floor garage (360 s.f.)  
R-0 continuous insulation, R-19 cavity insulation  
Insulation Grade: II
- Name: 2nd Floor Ambient (1,104 s.f.)  
R-0 continuous insulation, R-19 cavity insulation  
Insulation Grade: II

## Rim Joist

# Energy Code Inspection Checklist



**Property** \_\_\_\_\_ **Organization**  
Southern Energy Manager  
Justin Smith **Inspection Status**  
Results are projected

JSJ Builders - Maplewood plan  
CZ 4 - HERS  
Maplewood plan **Builder**  
JSJ Builders

Name: 1st Floor Ambient (96 s.f.)  
R: 17.30

Name: 1st floor garage (40 s.f.)  
R: 17.30

## Ceiling / Roof

Name: attic (1,139 s.f.)  
R-13 continuous insulation, R-25 cavity insulation  
Insulation Grade: I

## Opaque Door

Name: front entry (20 s.f.)  
U: 0.200

Name: garage entry (18 s.f.)  
U: 0.200

## Glazing

Name: front shaded (6.2 s.f.), U: 0.320, SHGC: 0.21, Orientation: EAST

Name: front 2nd unshaded (65.4 s.f.), U: 0.320, SHGC: 0.21, Orientation: EAST

Name: left 2nd unshaded (13.8 s.f.), U: 0.320, SHGC: 0.21, Orientation: SOUTH

Name: right 2nd unshaded (27.5 s.f.), U: 0.320, SHGC: 0.21, Orientation: NORTH

Name: rear unshaded (76.1 s.f.), U: 0.320, SHGC: 0.21, Orientation: WEST

Name: rear 2nd unshaded (43.5 s.f.), U: 0.320, SHGC: 0.21, Orientation: WEST

## Skylight

None Present

# Energy Code Inspection Checklist



Property	Organization	Inspection Status
JSJ Builders - Maplewood plan CZ 4 - HERS Maplewood plan	Southern Energy Manager Justin Smith  Builder JSJ Builders	Results are projected

## Mechanical Ventilation

None Present

## Mechanical Equipment

- Heat Pump • Electric • 100% Heating Load @ 8.2 HSPF, 100% Cooling Load @ 14 SEER
- Water Heating • Electric • 100% Hot Water Load @ 0.92 Energy Factor

## Air Leakage Control

- Test Status: Blower-door tested  
House is air-sealed as to achieve 1,353 CFM50 (4.80 ACH50) or less at final blower-door test.

### Infiltration Requirements for IECC in Climate Zone 4

- 2009 IECC Infiltration limit for the design home is 7 ACH50.
- 2012 IECC Infiltration limit for the design home is 3 ACH50.
- 2015 IECC Infiltration limit for the design home is 3 ACH50.
- 2018 IECC Infiltration limit for the design home is 3 ACH50.
- 2021 IECC Infiltration limit for the design home is 5 ACH50.

## Duct Leakage

### Duct System 1

- NOT entirely within conditioned space, testing required
- Leakage to Outside specified as: 76 CFM @ 25Pa (3.96 / 100 ft<sup>2</sup>)
- Total Leakage specified as: 76 CFM @ 25Pa (Post-Construction)

# Energy Code Inspection Checklist



<b>Property</b> ---	<b>Organization</b> Southern Energy Manager Justin Smith	<b>Inspection Status</b> Results are projected
JSJ Builders - Maplewood plan CZ 4 - HERS Maplewood plan	<b>Builder</b> JSJ Builders	

SOUTHERN ENERGY  
MANAGEMENT  
ENERGY EFFICIENCY & SUSTAINABILITY

## Duct Leakage Code Requirements for IECC

### 2009 IECC:

Postconstruction Leakage Test: Duct Leakage to Outdoors  $\leq 8$  CFM25 / 100 sq ft CFA.

Rough in Test with AHU: Total Duct Leakage  $\leq 6$  CFM25 / 100 sq ft CFA.

Rough in Test without AHU: Total Duct Leakage  $\leq 4$  CFM25 / 100 sq ft CFA.

### 2012 IECC Mandatory, 2015 and 2018 IECC Prescriptive Paths:

Postconstruction Leakage Test: Total Duct Leakage  $\leq 4$  CFM25 / 100 sq ft CFA.

Rough in Test with AHU: Total Duct Leakage  $\leq 4$  CFM25 / 100 sq ft CFA.

Rough in Test without AHU: Total Duct Leakage  $\leq 3$  CFM25 / 100 sq ft CFA.

### 2015 and 2018 IECC Performance Paths (Cost Compliance):

Leakage testing is required UNLESS all ducts and air handlers are located entirely within the thermal envelope.

There is no pass/fail threshold for duct leakage on the performance path.

## Project Notes

updated JS 02/17/22

- confirm HVAC specs
- confirm water heater specs
- modeled to worst case orientation
- confirm cfl lighting %
- confirm utilities