



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

5/24/2024

SUBJECT: SFD2206-0077
SINGLE FAMILY DWELLING

To: MCLEAN SIDNEY

Here are the results of all Inspections located at **1000 TIM CURRIN RD:**

Inspection Type: FOUNDATION SURVEY
Scheduled Date/Time:
Completed Date/Time:
Inspector: CP Bucket
Result:
Remarks:
Notes:

Inspection Type: GAS PIPING
Scheduled Date/Time:
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks:
Notes:

Inspection Type: OPEN FLOOR
Scheduled Date/Time:
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks:
Notes:

Inspection Type: SEWER CONNECTION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks:
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: TEMP POWER CERTIFICATION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks:
Notes:

Inspection Type: WATER CONNECTION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks:
Notes:

Inspection Type: FINAL SFD CRAWL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks:
Notes:

Inspection Type: ADDRESS
Scheduled Date/Time: 10/13/2023
Completed Date/Time: 10/16/2023
Inspector: GIS Bucket
Result: APPROVED
Remarks:
Notes: 1000 Tim Currin Rd
Lillington NC 27546

Inspection Type: T-POLE
Scheduled Date/Time: 10/19/2023
Completed Date/Time: 10/19/2023
Inspector: Daniel L Floyd
Result: APPROVED
Remarks:
Notes:





Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: FOOTING
Scheduled Date/Time: 10/19/2023
Completed Date/Time: 10/19/2023
Inspector: Daniel L Floyd
Result: DISAPPROVED
Remarks:
Notes: Footing already poured and no engineers letter on file or on site.

Inspection Type: FOOTING
Scheduled Date/Time: 3/1/2024
Completed Date/Time: 3/1/2024
Inspector: John B Kokoszka
Result: DISAPPROVED
Remarks:
Notes: eng letter will be in the permit box
Need 3rd party form signed

Inspection Type: FOUNDATION
Scheduled Date/Time: 3/1/2024
Completed Date/Time: 3/1/2024
Inspector: John B Kokoszka
Result: DISAPPROVED
Remarks:
Notes: eng letter will be in the permit box
Need 3rd party form signed

Inspection Type: FOUNDATION
Scheduled Date/Time: 3/6/2024
Completed Date/Time: 3/6/2024
Inspector: John B Kokoszka
Result: APPROVED
Remarks:
Notes: Inspector SPG changed the inspection assignment from SPG to JBK
Passed per 3d party form

Inspection Type: FOOTING
Scheduled Date/Time: 3/6/2024
Completed Date/Time: 3/6/2024
Inspector: John B Kokoszka
Result: APPROVED
Remarks:
Notes: Inspector SPG changed the inspection assignment from SPG to JBK





Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: Passed per 3d party form

Scheduled Date/Time:

Inspection Type: ROUGH IN

Scheduled Date/Time: 3/6/2024

Completed Date/Time: 3/6/2024

Inspector: John B Kokoszka

Result: DISAPPROVED

Remarks:

Notes: trades only per John

1. DWB no water test
2. Half bath missing midpoint strap on vent
3. No pressure test
4. No shower test
5. Nail plate guard for laundry room
6. Midpoint strap vent for laundry, missing
7. Missing nail guard for dryer wire, and washer wire
8. Missing nail guard at duplex receptacle by kitchen closet bottom plate
9. Small bathroom exhaust fan duck exceeds 14 feet flex
10. Missing midpoint strap for a vent pipe
11. Missing nail guard, small bathroom vent pipe, both sides
12. Need to fasten tub shroud right side small bath
13. Need secure duck vent in kitchen
14. Plumbing wasn't completed Note: the framing and floor system and roof system and all structural components was covered by the 3rd party form from the engineer

Inspection Type: ROUGH IN REINSPECT

Scheduled Date/Time: 3/8/2024

Completed Date/Time: 3/8/2024

Inspector: James T Hall

Result: FAIL W/ PENALTY

Remarks:

Notes: owner took pressure off, because he didnt wanted to burst.

12. Need to fasten tub shroud right side small bath
14. Plumbing wasn't completed under laundry room

Inspection Type: INSULATION

Scheduled Date/Time: 3/8/2024

Completed Date/Time: 3/8/2024

Inspector: James T Hall

Result: DISAPPROVED

Remarks:

Notes: Rough in didn't pass

Inspection Type: ROUGH IN REINSPECT

Scheduled Date/Time: 3/12/2024

Completed Date/Time: 3/12/2024

Inspector: James T Hall

Result: APPROVED

Remarks:

Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: INSULATION REINSPECTION

Scheduled Date/Time: 3/12/2024

Completed Date/Time: 3/12/2024

Inspector: James T Hall

Result: APPROVED

Remarks:

Notes:

Inspection Type: ENVIR OPERATIONS PERMIT

Scheduled Date/Time: 3/22/2024

Completed Date/Time: 3/22/2024

Inspector: Mark Osborne

Result: APPROVED

Remarks:

Notes: