

		Products			
PlotID	Length	Product	Plies	Net Qty	Fab Typ
Bk1	2-0-0	14" NI-40x	1	1	FF
DB1	7-0-0	1-3/4"x 9-1/4" LVL Kerto-S	2	2	FF
FB1	12-0-0	1-3/4"x 14" LVL Kerto-S	2	2	FF
FB2	24-0-0	1-3/4"x 23-7/8" LVL Kerto-S	4	4	FF
FB3	13-0-0	1-3/4"x 14" LVL Kerto-S	2	2	FF
FJ1	35-3-6	14" NI-40x	1	8	FF
FJ1A	35-5-4	14" NI-40x	1	1	FF
FJ2	19-10-8	14" NI-40x	1	1	FF
FJ3	19-7-14	14" NI-40x	1	5	FF
FJ4	16-0-12	14" NI-40x	1	1	FF
FJ5	15-11-13	14" NI-40x	1	6	FF
FJ6	15-9-9	14" NI-40x	1	5	FF
FJ7	15-9-3	14" NI-40x	1	6	FF
FJ8	4-1-2	14" NI-40x	1	1	FF
FJ9	3-9-9	14" NI-40x	1	1	FF
Front Load GDH	24-0-0	1-3/4"x 11-7/8" LVL Kerto-S	3	3	FF
RIM1	12-0-0	1 1/8" x 14" Rim Board	1	11	FF
Side Load GDH	24-0-0	1.75 X 24 Kerto-S LVL 2.0E	3	3	FF
Triple Window Header	10-0-0	1-3/4"x 11-7/8" LVL Kerto-S	2	2	FF

	THF25140-2	USP	01	NA	10d/3"	10d/3"
	THF25140	USP	32	NA	10d/3"	10d/3"

Truss Placement Plan

= Indicates Left End of Truss
(Reference Engineered Truss Drawing)
Do NOT Erect Truss Backwards

		ΠÞ	ИC	V V II	iuc	J V V	1 100	aut	7
_									_
	LO	AD (CHAF	RT FO	RЈ	ACK :	STUD	s	
	NU/			N TABLE:					
				HEADER/					
	END REACTION (UP TO)	REQ D STUDS FOR (2) PLY HEADER		END REACTION (UP TO)	REQ'D STUDS FOR (3) PLY HEADER		END REACTION (UP TO)	REQ'D STUDS FOR (4) PLY HEADER	
	1700	1		2550	1		3400	1	
	3400	2		5100	2		6800	2	
	5100	3		7650	3		10200	3	
	6800	4		10200	4		13600	4	
	8500	5		12750	5		17000	5	
	10200	6		15300	6				
	11900	7							
	13600	8							
	15300	9							

10-0-0	1-3/4 X 11-7/0 EVE Reft0-3 2 2	1.1	SCALE: 1/4"=1"	Do r	
BUILDER	Caviness & Cates Building & Development	CITY / CO.	Cameron / Harnett	THIS IS A TRUSS PLACEMENT DIAGRAM ONLY. These trusses are designed as individual building components to be incorporated into the building design at the specification of the building designer. See individual design sheets for each truss design identified on the placement drawing. The building designer	
JOB NAME	Lot 67 Anderson Creek	ADDRESS	275 Timber Skip Dr.	is responsible for temporary and permanent bracing of the roof and floor system and for the overall structure. The design of the truss support structure including headers, beams, walls, and columns is the responsibility of the building designer. For general guidance regarding bracing, consult BCSI-B1 and BCSI-B3 provided with the truss delivery package or online @ sbcindustry.com	
PLAN	CC 2136 2ND Floor RF I-Joist w/Nook	MODEL	31500	Bearing reactions less than or equal to 3000# are deemed to comply with the prescriptive Code requirements. The contractor shall refer to the attached Tables (derived from the prescriptive Code requirements) to determine the minimum	
SEAL DATE	5/21/21	DATE REV.	06/14/22	foundation size and number of wood studs required to support reactions greater than 3000# but not greater than 15000#. A registered design professional shall be retained to design the support system for any reaction that exceeds those specified in the attached Tables. A registered design professional shall be	
QUOTE#	MOORE A&B RP3C	DRAWN BY	Marshall Naylor	retained to design the support system for all reactions that exceed 15000#. Marshall Naylor Signature	
JOB#	J0522-2638	SALES REP.	Scot Duncan	Marshall Naylor	



Fayetteville, N.C. 28309 Phone: (910) 864-8787 Fax: (910) 864-4444