

THIS LAYOUT IS TO BE USED AS A TRUSS PLACEMENT GUIDE ONLY.
 PLEASE REFER TO BUILDING PLANS FOR BUILDING CONSTRUCTION AND DETAILS,
 SUCH AS PLUMBING OR DUCT DROPS.

**PROPOSED DESIGN-
 NOT FOR
 CONSTRUCTION**

Job #
Q-2200715

Tommy Compton
 Lillington NC

Date Quoted:

Designer:
Thomas Cantwell

Valued Customer

**Peak Truss
 Builders, LLC**
 PO Box 340, New Hill, NC 27562

Roof Truss Loading per
 2018 NC Residential Code
 Top Chord Live Load 20# PSF
 Top Chord Dead Load 10# PSF
 Bottom Chord Live Load 0# PSF
 Bottom Chord Dead Load 10# PSF

Trusses are designed for additional
 storage load wherever a 42"x24"
 box will fit between the webs.

- △ - This symbol denotes left end of truss as shown on truss drawings
- - Approximate location of toilet drop. Builder please confirm.

Truss connections by others:

- ⊕ -Nailed
- ⊖ -Ledger

- Notes:
1. Exterior dimensions shown are assumed to be:
 - Out-to-out of stud
 - ⊗ Out-to-out of sheathing
 2. Adjust truss locations as needed for plumbing and mechanical clearance. Unless otherwise noted, trusses may be shifted as long as O.C. spacing shown is not exceeded.
 3. Do not cut, drill, or otherwise damage any part of any truss without prior approval from Peak Truss.
 4. Do not approve drawings if any information herein is unclear. Once ordered trusses will be fabricated as approved.
 5. Please contact Peak Truss Builders with any questions. We are available to help any way we can. We can be reached at 919-545-5555 or sales@peaktruss.com

Tommy Compton
 Roof trusses
 1'OH, 2'OC

