

July 7, 2022

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Joshua Jones
2661 NC 55 W
Coats NC 27521

ph: 910-893-7547
fax: 910-893-9371

Re: Status of Improvement Permit Application: SFD2206-0113

Mr Jones:

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible. (*\$25.00 fee incurred*)
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. **Other- Multiple Issues – Incorrect site plan setbacks. Front and rear setbacks appear closer than on site plan. Revise accordingly. No property lines marked. Mark property lines with provided flags or stakes. Existing well proximity is unapproved. Well abandonment application shall be applied for prior to any permit approvals. Site is home to a former Single Wide Mobile Home. Existing septic tank and drain field shall be located and identified prior to any permit approvals. Coordinate with a licensed septic contractor or septic pumper.**

Your application will be put on hold until the selected items above have been addressed.

When completed, **please call Central Permitting at 910-893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns please call 910-893-7547.

Sincerely,



Andrew Currin, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

AC/slc

Copy: Central Permitting

strong roots • new growth