## Harnett County Department of Public Health


## Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 17 Mary Robertson St. (NC 82) ISSUED TO: H & H Constructors of Fayetteville, LL SUBDIVISION Schabert Crossing Site Improvements required prior to Construction Authorization Issuance: REPAIR EXPANSION | Type of Structure: 28'x41' sfd, 3 beds 2.5 baths Proposed Wastewater System Type: 25% Reduction Sys. Projected Daily Flow: 360 Number of Occupants: 6 Number of bedrooms: 3 Basement Yes May be required based on final location and elevations of facilities Pump Required: XYes No X Five years Type of Water Supply: Community Public Well Distance from well NA feet Permit valid for: ■ No expiration Permit conditions: Committee Date: 08/03/2022 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules 1950, 1952, 1954, 1955, 1956, 1957, 1958 and 1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: H & H Constructors of Fayetteville, PROPERTY LOCATION: 17 Mary Robertson St. (NC 82) SUBDIVISION Schabert Crossing Facility Type: 28x41 sfd, 3 beds 2.5 bat New Expansion Repair Basement Fixtures? Yes Basement? Yes X No (Initial) Wastewater Flow: 360 Type of Wastewater System\*\* PUMP TO 25% NEOSCHON STORM (See note below, if applicable ) PUMP TO 50% TED. PPBPS Number of trenches Installation Requirements/Conditions Exact length of each trench 70 Septic Tank Size 1000 gallons Trenches shall be installed on contour at a Pump Tank Size \_\_\_\_\_ gallons Maximum Trench Depth of: 18 (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) inches below pipe Pump Requirements: ft. TDH vs. inches above pipe Conditions: RUMP TO MEDIUM D-BOX REGULAR DISTRIBUTION WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH 08/03/2072

ANDREW

Construction Authorization Expiration Date: 08/03/2027

## Harnett County Department of Public Health Site Sketch



MARY ROBERTSON STREET

This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.