



(Reference Engineered	I Truss Drawin	a)		HANGER LEGEND		
Do Not Erect Truss	·	37		= USP HUS26 / Single 2x Hanger		
LOAD CHART FOR JACK STUDS 0.0455 ON 14025-18025() 4-60	BUILDER	Wellco	Contr	ractors CITY /		

Truss Placement Plan SCALE: 1/4" = 1'
--

Beam Legend							
PlotID	Length	Product	Plies	Net Qty	Fab Type		
BM1	7' 0"	1-3/4"x 9-1/4" LVL Kerto-S	2	2	FF		
GDH	21' 0"	1-3/4"x 11-7/8" LVL Kerto-S	2	2	FF		
BM2	4' 0"	2x8 SPF No.2	2	2	FF		

(3679H KW(0))	BUILDER	Wellco Contractors	CITY / CO.	Spring Lake / Harnett	THIS IS A TRUSS PLAC These trusses are designed the building design at the sp sheets for each truss design is responsible for temporary the overall structure. The de walls, and columns is the re- regarding bracing, consult B or online @ sbcindustry.com Bearing reactions less tha prescriptive Code requirer (derived from the prescriptive Code requirer (derived from the prescription of the specified in the attached I retained to design the specified in the attached I retained to design the sup	
	JOB NAME	Lot 110 Hidden Lakes	ADDRESS	Site Address		
	PLAN	Plan 2	MODEL	Model		
	SEAL DATE	Seal Date	DATE REV.	07/14/22		
	QUOTE #	B0522-2881	DRAWN BY	Curtis Quick		
	JOB #	J0722-3667	SALES REP.	Lenny Norris		

THIS IS A TRUSS PLACEMENT DIAGRAM ONLY.

These trusses are designed as individual building components to be incorporated into the building design at the specification of the building designer. See individual design sheets for each truss design identified on the placement drawing. The building designer is responsible for temporary and permanent bracing of the roof and floor system and for the overall structure. The design of the truss support structure including headers, beams, walls, and columns is the responsibility of the building designer. For general guidance regarding bracing, consult BCSI-B1 and BCSI-B3 provided with the truss delivery package or online @ sbcindustry.com

Bearing reactions less than or equal to 3000# are deemed to comply with the

reactions less than or equal to 3000# are deemed to comply with the rescriptive Code requirements. The contractor shall refer to the attached Tables derived from the prescriptive Code requirements) to determine the minimum bundation size and number of wood studs required to support reactions greater ann 3000# but not greater than 15000#. A registered design professional shall be retained to design the support system for any reaction that exceeds those pecified in the attached Tables. A registered design professional shall be etained to design the support system for all reactions that exceed 15000#.

Curtis Quick

Curtis Quick



Reilly Road Industrial Park Fayetteville, N.C. 28309 Phone: (910) 864-8787 Fax: (910) 864-4444