


- \*Keep tanks and drain lines 10' from property lines.
- \*Not a survey.
- \*Not a guarantee of a septic permit.
- \*Keep supply lines >5' from property lines.
- \*Some lines are flagged longer in the field than lengths indicate.
- \*No grading septic area.

|  |
|--|
| System: Pump to D-Box<br>Lines: 1-3, (4x80'x3')<br>Accepted Status System<br>0.4 Soil LTAR |
| Repair: Pressure Manifold<br>Lines: 4-6, (285')<br>Accepted Status System<br>0.4 Soil LTAR |



Central Carolina Soil Consulting, PLLC  
 1900 South Main Street, Suite 110  
 Wake Forest, North Carolina 27587  
 Phone (919)569-6704 Fax (919)569-6703

4-Bedroom Septic Layout  
 Lot 186, Birchwood Subdivision  
 Harnett County, North Carolina

|                  |
|------------------|
| Job# : 3753      |
| Drawn By : LW    |
| Date : 7/20/2022 |
| Revision:        |
|                  |
|                  |