

August 19, 2022

Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

H&H Constructors of Fayetteville LLC  
3709 Raeford Road Suite 200  
Fayetteville NC 28304

ph: 910-893-7547  
fax: 910-893-9371

**Re: Status of Improvement Permit Application: SFD2207-0073  
48 Betty Ann St**

To whom it may concern:

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible. (*\$25.00 fee incurred*)
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. **Other: Unable to approve as applied. Shallow unsuitable soils present in rear yard. Land use/site plan shall be consistent with proposal from Lot 1 (22 Betty Ann). 3-Bedroom Max. Driveway along property line. Front setback approximately 100ft. Revise application accordingly. Reconfirm when ready.**

Your application will be put on hold until the selected items above have been addressed.

When completed, **please call Central Permitting at 910-893-7525 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation. If you have any questions or concerns please call 910-893-7547.

Sincerely,



Andrew Currin, R. E. H. S.  
Environmental Health Program Specialist  
Harnett County Department of Public Health

AC/slc

Copy: Central Permitting