

DESIGN PROFESSIONAL INSPECTION FORM

RECORD OF THE INSPECTION OF A **COMPONENT OR ELEMENT** BY A NC LICENSED ARCHITECT OR ENGINEER

Project Information:

Residential Single-Family Project: <input checked="" type="radio"/> Y <input type="radio"/> N	Commercial Project: <input type="radio"/> Y <input type="radio"/> N
Code Enforcement Project No:	Permit No: #SFD2207-0098
Project Name: Single Family Addition	Owner/Permit Holder: VGG Holdings LLC.
Project Address: 32 Stonecliff Lane Sanford, N.C.	Suite No:
Date Inspected: June 19, 2023	Contractor Name: Gitto Enterprises
Component Inspected: Foundation Excavation	

Responsible Licensed NC Architect or NC Engineer

Name:	Ronald B. Wilkins, P.E.		
Firm Name:	Wilkins Engineering, PC		
Phone Numbers:	Office: 919.772.3540	Mobile: 919.601.4924	
Email Address:	wilkinsengr@aol.com		
Mailing Address:	P.O. Box 37446, Raleigh, NC 27627		

APPLICABLE CODE: 2018 North Carolina Residential Building Code

2018 NCBC = 2018 NC Building Code; 2018 NCRC = 2018 NC Residential Code

Describe Element/Component/Type of Inspection: * Foundation excavation was inspected prior to the placement of concrete. All footing excavations noted on the approved plans were inspected by probing the subgrade and visual inspection to verify no water or suspect areas existed. The subgrade was a firm, sandy material with no soft or suspect areas identified. The condition of the subgrade meets the requirements of the 2018 NC Residential Code and fresh concrete should be placed as soon as practical.


*(subgrade form/letter may also be required)

Attestation/Signature:

By signing below, I certify that the component and/or element of the building as identified on this form has been inspected by me or someone under my direct supervision per subsection (b2) of NC G.S. 153A-352 and is in compliance with the Code or other proposal of the architect or engineer for the project. This inspection is in compliance with all of the requirements of the above referenced Code. Attach any additional documents if needed.

Ronald B. Wilkins, P.E.

Licensed Architect or Engineer



Inspection Department disclaimer:

Upon the receipt of a signed written document as required under subsection (a) of Article 160A-413.5., Code Enforcement shall be discharged and released from any liabilities, duties and responsibilities imposed by this article or in common law from any claim arising out of or attributed to the component or element in the construction of the building for which the signed written document was submitted. Be aware that this inspection will be noted in all inspection records including the Certificate of Occupancy or Certificate of Compliance. This inspection does not address any local ordinances or zoning requirements.