

Harnett County Department of Public Health

PERMIT # SED 2208-0007

Operation Permit

New Installation Septic Tank Nitrification Line Repair Expansion

PROPERTY LOCATION: OL 1769 OLD STAGE RD

Name: (owner) Freedom Constructors SUBDIVISION Wildwood LOT # 1

System Installer: Clint Adams

Basement with plumbing: Garage Number of Bedrooms 3

Type of Water Supply: Community Public Well Distance from well _____ feet


System Type: 25% REDUCTION System Type III G Types V and VI Systems expire in 5 years.

(In accordance with Table V a)

Owner must contact Health Department 6 months prior to expiration for permit renewal.

EZ FLOW

This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.



PERMIT CONDITIONS:

- I. Performance: System shall perform in accordance with Rule .1961.
- II. Monitoring: As required by Rule .1961.
- III. Maintenance: As required by Rule .1961. Other: 25% REDUCTION Repair
Subsurface system operator required? Yes No AREA
If yes, see attached sheet for additional operation conditions, maintenance and reporting.
- IV. Operation: _____
- V. Other: _____

D-Box Pump Alarm H2O Line PWR Line

Following are the specifications for the sewage disposal system on the above captioned property.

Type of system: Conventional Other 25% REDUCTION Septic Tank: 1000 gallons Pump Tank: _____ gallons
 Subsurface No. of exact length width of depth of
 Drainage Field ditches 3 of each ditch 85 feet ditches 3 feet ditches 26-18 inches
 French Drain Required: _____ Linear feet

Authorized State Agent James E. Markant Date 3-15-23


Application # SFD2208-0007

Harnett County Department of Public Health Site Sketch

Property Location: 55 Ramble Falls Ln. (Old Stage Rd. N. - SR 1769)

Issued To: Freedom Constructors, Inc. Of Dunn Subdivision Wildwood Lot # 1

Authorized State Agent: [Signature] Date: 09/20/2022



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.