

Harnett County Department of Public Health Improvement Permit

A building permit cannot be issued with only an Improvement Permit

PROPERTY LOCATION: 737 S LINCOLN ST (COATS)
SUBDIVISION SEVEN MAGNOLIAS LOT # 3A

ISSUED TO: SEVEN MAGNOLIAS CONSTRUCTI

NEW REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance: _____

Type of Structure: 30'x55' SFD - 3-BED.

Proposed Wastewater System Type: 25% REDUCTION SYS

Projected Daily Flow: 360 GPD

Number of bedrooms: 3 Number of Occupants: 6 max

Basement Yes No

Pump Required: Yes No May be required based on final location and elevations of facilities

Type of Water Supply: Community Public Well Distance from well NA feet

Permit valid for: Five years No expiration

Permit conditions: _____

Authorized State Agent: [Signature] Date: 08/24/2022 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization (Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: SEVEN MAGNOLIAS CONSTRUC PROPERTY LOCATION: 737 S LINCOLN ST (COATS)
SUBDIVISION SEVEN MAGNOLIAS LOT # 3A

Facility Type: 30'x55' SFD - 3-BED. New Expansion Repair

Basement? Yes No Basement Fixtures? Yes No

Type of Wastewater System** 25% REDUCTION SYSTEM (Initial) Wastewater Flow: 360 GPD

(See note below, if applicable) 25% REDUCTION SYSTEM (Repair)

| | | |
|--|--|---|
| Installation Requirements/Conditions | Number of trenches <u>3</u> | |
| Septic Tank Size <u>1000</u> gallons | Exact length of each trench <u>80</u> feet | Trench Spacing: <u>9</u> Feet on Center |
| Pump Tank Size _____ gallons | Trenches shall be installed on contour at a Maximum Trench Depth of: <u>18-20</u> inches (Trench bottoms shall be level to +/-1/4" in all directions) | Soil Cover: <u>6-8</u> inches (Maximum soil cover shall not exceed 36" above the trench bottom) |
| Pump Requirements: _____ ft. TDH vs. _____ GPM | | Aggregate Depth: <u>NA</u> inches below pipe <u>NA</u> inches above pipe <u>NA</u> inches total |

Conditions: GRAVITY TO D-BOX EQUAL DISTRIBUTION REQUIRED

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 08/24/2022
ANDREW CURRIN Construction Authorization Expiration Date: 08/24/2027

Application # SFD2208-0016

Harnett County Department of Public Health Site Sketch

Property Location: 737 S LINCOLN ST (COATS)

Issued To: SEVEN MAGNOLIAS CONSTRUCTION INC Subdivision SEVEN MAGNOLIAS Lot # 3A

Authorized State Agent: *[Signature]*

Date: 08/24/2022

* GRAVITY TO D BOX
EQUAL DISTRIBUTION
REQUIRED

* INSTALL AS HIGH UP HILL
AS CONTOUR ALLOWS



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.