

ROOF & FLOOR

TRUSSES & BEAMS
Reilly Road Industrial Park

Fayetteville, N.C. 28309 Phone: (910) 864-8787 Fax: (910) 864-4444

Bearing reactions less than or equal to 3000# are leemed to comply with the prescriptive Code requirements. The contractor shall refer to the attached Tables (derived from the prescriptive Code equirements) to determine the minimum foundation size and number of wood studs required to support eactions greater than 3000# but not greater than 15000#. A registered design professional shall be retained to design the support system for any eaction that exceeds those specified in the attacher lables. A registered design professional shall be retained to design the support system for all reactions that exceed 15000#.

nature Marshall Naylor

Marshall Naylor

LOAD CHART FOR JACK STUDS

(BASED ON TABLES R502.5(1) & (b))

ADDRESS 61 Solomon Dr.

MODEL Floor

DATE REV. 08/04/22

DRAWN BY Marshall Naylor

SALES REP. Marshall Naylor

THIS IS A TRUSS PLACEMENT DIAGRAM ONLY.

These trusses are designed as individual building components to be incorporated into the building design at the specification of the building design at the specification of the building designer. See individual design sheets for each truss design identified on the placement drawing. The building designer is responsible for temporary and permanent bracing of the roof and floor system and for the overall structure. The design of the truss support structure including headers, beams, walls, and columns is the responsibility of the building designer. For general guidance regarding bracing, consult BCSI-B1 and BCSI-B3 provided with the truss delivery package or online @ sbcindustry.com

J0822-3984

Quote#

Ben Stout Real Estate

Lot 53 Liberty A