

NORTH CAROLINA ENERGY CODE COMPLIANCE CERTIFICATE*
 (2018 NC Energy Code Section 401.3)

Builder, Permit Holder, or Registered Design Professional

Print Name: Chad Anderson

Signature: Chad Anderson

Property Address: 5210 Old US Hwy 421

Date: 8-6-24

Building Air Leakage

- Visually Inspected according to 402.4.2.1 OR
- Building Air Leakage Test Results
 (Sec. 402.4.2.2)
 ACH50 [Target: 5.0] or
 CFM50/SFSA [Target: 0.30]

Name of Tester/Company: _____

Date: _____ Phone: _____

Insulation Rating - List the value covering largest area to all that apply R-Value

Ceiling/Roof: _____ R- _____

Wall: _____ R- _____

Floor: _____ R- _____

Closed Crawl Space Wall: _____ R- _____

Closed Crawl Space: _____ R- _____

Slab: _____ R- _____

Basement Wall: _____ R- _____

Fenestration: _____

U-Factor: _____

Solar Heat Gain Coefficient (SHGC): _____

Ducts: _____

Insulation: _____ R- 8

Total-Duct Leakage Test Result (Sect. 403.2.2)

(CFM25 Total/100SF) [Target: 6] 3.6

Name of Tester/Company: MY HVAC Guys

Date: 8-6-24 Phone: 919-958-8002

Certificate to be displayed permanently.

*A permanent certificate shall be posted on or in the electrical distribution panel, inside the kitchen cabinet or other approved location. List primary type when there is more than one value for each component (i.e. certificate shall list the value covering the largest area). Required testing shall be performed and reported by the permit holder, a NC licensed general contractor or NC licensed HVAC contractor, a NC licensed Home Inspector, a registered design professional, a certified BPI Envelope Professional or a certified HERS rater.