

Space for Architect Seal

Plan Review: 08/10/2022

▼ Fenestration Calculations:

Total Fenestration %:

ADD FIRE PROTECTION TO SIDE ELEVATIONS PER COMMUNITY SPEC'S

- REMOVE OPT. 3RD FLOOR

FOR STRUCTURE

Total Wall Square Footage: 4105.66 Total Window Square Footage: 466

11.35%

RESIDENCE FOR:

MARKET

SERENITY

06/16/2022

Architecture Plan Review: □ No Comments See Comments Items drawn on any drawings and not written in the contract selctions <u>WILL NOT</u> be included in the site specific drawings. Customer Plan Review Signature Customer Request: Design Solution: Reason For Modification: 1. "27-HVAGAS02 GAS TYPE - NATURAL GAS" I. NOT SHOWN . LOCATION NOT PROVIDED . PLEASE PLACE IN THE DESIGN CENTER for my house. Drees draws the standard plans complete with the most common options. The subcontractor's sets will show only the options I selected in my 2. XXX 2. XXX 2. XXX 2. XXX 3. XXX 3. XXX 3. XXX 3. XXX may occur since every home that is built has it's own set of unique construction problems that must be dealt with as the home is being built. Customer: __ 4. XXX 4. XXX 4. XXX 4. XXX Date:

understand that my new Drees home will be built in general comformance to the plans, specifications, selections and the Purchase Agreement, all of which I have reviewed and approved. This set of plans may not reflect the elevations or options selection sheets. I have reviewed the plot plan for my house and understand that there may be some field adjustments as to the exact location of the house on the lot. I further understand that my home will not be built exactly like any other Drees home or Model and that some minor variations from my plans and specifications

HOMES_{SM} Copyright © 2019, (2019) The Drees Company. All Rights Reserved. 7701 Six Forks Road, Suite 132, Raleigh, NC 27615 Phone: [919] 844-9288

the EPIPHANY

Job Number

House Name:

STY5-0027-00

Drawing Scale: 1/8" = 1'0"

GREG P.

Elevation "B"

Plan No.

859-578-4355

CLASSIC


PLAN NM


GENERAL NOTES - RALEIGH FOUNDATION NOTES CRAWL SPACES: **BASEMENTS:** SLOPE CONCRETE SLAB 4" MINIMUM TOWARDS GARAGE DOOR - SLOPE CONCRETE SLAB 4" MINIMUM TOWARDS GARAGE DOOR - EXTERIOR FLATWORK/GARAGES SHALL HAVE A MINIMUM CONCRETE SRENGTH OF 4,500 PSI - EXTERIOR FLATWORK/GARAGES SHALL HAVE A MINIMUM CONCRETE SRENGTH OF 4,500 PSI FOOTINGS TO A MINIMUM CONCRETE STRENGTH OF 2500 PSI, UNLESS OTHERWISE NOTED - FOOTINGS TO A MINIMUM CONCRETE STRENGTH OF 2500 PSI, UNLESS OTHERWISE NOTED- ALL FOUNDATION WALLS TO BE CAST IN PLACE CONCRETE 3000 PSI MIN, UNLESS OTHERWISE ASSUMED ALLOWABLE SOIL BEARING PRESSURE: 2.000 p.s.f. WATERPROOF FOUNDATION WITH BITUMINOUS SPRAY. - BASEMENT WINDOW LOCATIONS MAY VARY FROM DRAWING DUE TO LOT CONDITIONS. WALL TIES EMBEDDED IN THE HORIZONTAL MORTAR JOINT SHALL BE 16" ON CENTER, TIES IN ALTERNATE COURSES SHALL BE STAGGERED. - BACKFILL ADJACENT TO FOUNDATION WALLS SHALL NOT BE PLACED UNTIL THE WALL HAS SUFFICIENT STRENGTH AND HAS BEEN ANCHORED TO THE FLOOR OR HAS BEEN SUFFICIENTLY THE MAXIMUM VERTICAL DISTANCE BETWEEN TIES SHALL NOT EXCEED 16" AND THE MAXIMUM HORIZONTAL DISTANCE SHALL NOT EXCEED BRACED TO PREVENT DAMAGE BY THE BACKFILL. - ASSUMED ALLOWABLE SOIL BEARING PRESSURE: 2,000 p.s.f. 16" ADDITIONAL TIES SHALL BE PROVIDED AT ALL OPENINGS, AND WITHIN 12" OF THE OPENING CORE FILL ENTIRE BLOCK WALL WHEN THE WALL IS 4'-0" TALL OR HIGHER. INSTALL #4 REBAR IN EACH HOLLOW AREA OF EACH BLOCK - WATERPROOF FOUNDATION WITH BITUMINOUS SPRAY. FROM FOOTING TO TOP OF WALL, ON THE ENTIRE WALL PRIOR TO CORE FILLING IT. - VERTICAL CONTROL JOINTS IN BASEMENT FOUNDATION WALLS - STANDARD LOCATION GUIDELINES: 1) PLACE A CONTROL JOINT IN ALL UNBRACED WALLS OVER 30' IN LENGTH. (NOTE: "T" WALLS AND CORNERS COUNT AS A BRACE). TOP COURSE OF BLOCK ON ALL WALLS WILL BE FILLED SOLID WITH MORTAR PLACING THE FOUNDATION STRAPS OR BOLTS IN THE MORTAR 2) WINDOWS THAT ARE LARGER THAN THE STANDARD BASEMENT WINDOW REQUIRE A CONTROL JOINT. 6'-0" ON CENTER, AND 12" FROM EACH CORNER 12"x16" PIERS: HOLLOW MASONRY UP TO 48" HIGH, SOLID MASONRY UP TO 9'0" HIGH 3) CONTROL JOINTS ARE NOT REQUIRED AT EVERY WINDOW THAT IS STANDARD SIZE 16"x16" PIERS: HOLLOW MASONRY UP TO 64" HIGH, SOLID MASONRY UP TO 12'0" HIGH 4) IF THERE IS A STANDARD WINDOW LOCATED IN A WALL SEGMENT THAT REQUIRES A CONTROL JOINT, THEN THE CONTROL JOINT SHOULD BE PLACED ON THE SIDE OF THE WINDOW - BLOCK PIERS SHOULD BE PLACED DIRECTLY ON CONCRETE FOOTINGS PER PLAN. THEY SHOULD BE PLUMBED AND SQUARE WITHIN 1/4". that is adjacent to the long side of the wall. If there is more than one window in a wall then only one window should have a control joint. - SILL PLATES TO BE A MINIMUM OF 2x4 NOMINAL LUMBER. 5) DOORS DO NOT GET CONTROL JOINTS. 6) CONTROL JOINTS SHOULD NOT BE LOCATED WITHIN 3' OF A BEAM POCKET. 7) CONTROL JOINTS ARE REQUIRED AT THE FIRST AND LAST STEP DOWN AT STEPPED BASEMENT FOUNDATION WALLS. - INTERIOR FLATWORK SHALL HAVE A MINIMUM CONCRETE STRENGTH OF 3,000 PSI. - ALL VERTICAL STEEL AND ALL STEEL IN STRUCTURAL SLABS TO BE GRADE 60, ALL HORIZONTAL STEEL IN FOUNDATION WALLS AND FOOTERS TO BE GRADE 40 STEEL FRAMING NOTES MECHANICAL/ELECTRICAL NOTES DESIGN LOADS: - ANY GAS APPLIANCES MUST BE INSTALLED PER MANUFACTURER'S SPECIFICATIONS FLOORS: 40 psf LIVE LOAD + 10 psf DEAD LOAD = 50 psf GARAGE FLOOR: 50 psf LIVE LOAD SEISMIC: "A" & "B" - HOLD THE CENTERLINE OF ALL EXTERIOR LIGHT FIXTURES AT 5'-8" OFF BOTTOM OF DOOR OPENING. ROOF: 18 psf LIVE LOAD + 17psf DEAD LOAD = 35 psf WIND SPEED: 120 MPH - ALL KITCHEN CABINET DIMENSIONS ARE CABINET TO CABINET DESIGN DEFLECTION LIMITS (BASED ON LIVE LOAD, EXCEPT MASONRY): - CABINET STYLES MAY VARY FROM INTERIOR ELEVATIONS DEPENDING ON STYLE, MANUFACTURER, ETC. FOR CABINET RAFTERS GREATER THAN 3:12 L/180 **CEILINGS** L/240 DETAILS SEE SHOP DRAWINGS. MASONRY VENEER L/600 - CABINET SIZES MAY VARY WITH FULL-OVERLAY CABINETS. NOMINAL LUMBER FLOORS: L/360 - GROUND FAULT INTERRUPTER (GFCI) OUTLETS TO BE INSTALLED PER NEC 2017, SECT. 210.8 MANUFACTURED WOOD FLOORS: DESIGNED TO MINIMUM PRO RATING OF 35 (OR EQUIVALENT). - PROVIDE HOSE BIBS PER DIVISION SPEC. SHEET. EXACT LOCATION TO BE FIELD DETERMINED UNLESS OTHERWISE NOTED NO MORE THAN 8 POINT DIFFERENCE BETWEEN ADJACENT SPANS. ON THE PLANS. L/480 FOR SPANS UP TO 16'-0" AND NO GREATER THAN 1/2" DEFLECTION - MIN. 50 C.F.M. FOR ALL EXHAUST FANS IN BATHROOMS L/600 FOR SPANS OVER 16'-0" IF SIMPLE SPAN AND NO GREATER THAN 1/2" DEFLECTION Space for Architect Seal L/840 FOR SPANS OVER 16'-0" IF CONTINUOUS SPAN. AND NO GREATER THAN 1/2" DEFLECTION INSULATION DETAILS 19.2" o.c. MAXIMUM SPACING JOIST SPACING: EXTERIOR STUD WALL CAVITY: R-15 DOUBLE EVERY OTHER FLOOR JOIST UNDER KITCHEN ISLANDS INSTALL UNCOUPLING MEMBRANE IN TILE FLOOR AREAS IF 19.2" o.c. FLOOR JOIST SPACING FLOOR JOIST CAVITY AT STANDARD PERIMETER: R-19 GLUE AND MECHANICALLY FASTEN [SCREWS] WOOD FLOOR IF 19.2" o.c. FLOOR JOIST SPACING FLOOR JOIST CAVITY AT CANTILEVER: R-19 MANUFACTURED WOOD PRODUCTS (INCLUDING, BUT NOT LIMITED TO, STRUCTURAL WOOD BEAMS AND I-JOISTS) SHALL BE FABRICATED. OVER GARAGE: (OVER HORIZONTAL SPACE) R-38 BLOWN HANDLED, AND INSTALLED IN ACCORDANCE WITH THE MANUFACTURER'S INSTRUCTIONS. (SLOPED AND VERTICAL SPACE) R-38 BATT -JOISTS ARE NOT TO BE PLACED DIRECTLY OVER INTERIOR PARALLEL WALLS. (TO PREVENT UNEVEN FLOOR DEFLECTION FROM OCCURRING) ALL WOOD BEAMS/HEADERS: 2x6's TO BE SPF STUD GRADE OR BETTER/ 2x8 OR LARGER TO BE SYP #2 [PER NDS 2012] OR BETTER ALL HEADERS SHALL BE SUPPORTED BY (1) 2x JACK STUD AND (1) 2x KING STUD MINIMUM. THE NUMBER OF STUDS SPECIFIED AT A SUPPORT INDICATES THE NUMBER OF JACKS REQUIRED, U.N.O. AT FLUSH OR DROPPED BEAMS, THE NUMBER OF STUDS SPECIFIED INDICATES THE TOTAL NUMBER OF STUDS REQUIRED TO SUPPORT THE BEAM EXTERIOR WALLS TO BE 2x4 SPF STUD GRADE AT 16" O.C. UNLESS OTHERWISE NOTED (10'4-1/2" MAXIMUM WALL HEIGHT) ALL INTERIOR BEARING WALLS AND WALLS AT BASEMENT & FIRST FLOOR STAIRWELLS, KITCHEN, BATH, & GARAGE TO BE 2x4 SPF STUD GRADE @ 16" o.c.; ALL OTHER NON-BEARING INTERIOR WALLS TO BE 2x4 SPF STUD GRADE @ 24" o.c. U.O.N. ALL WALLS TO BE 3 1/2" UNLESS OTHERWISE NOTED. FI EVATION NOTES PROVIDE SOLID BEARING TO FOUNDATION OR BEAM BELOW FOR ALL BEAMS, HEADERS & GIRDER TRUSSES. PROVIDE BLOCKING BETWEEN JOISTS WINDOW STYLE AND MULLIONS MAY VARY FROM ELEVATION DEPENDING UPON MANUFACTURER. STYLE, PATTERN, TYPE, AS REQUIRED. SEE SELECTION SHEET FOR SIZE AND STYLE OF FIREPLACE. SEE FIREPLACE ELEVATION DETAIL FOR ADDITIONAL FRAMING REQUIREMENTS, IF ANY. - USE SECONDARY HEAT BARRIER ON ALL DIRECT VENT FIREPLACES 7' OR LESS ABOVE A WALKWAY. CHECK SELECTION SHEETS FOR FLOOR COVERING AT TOP AND BOTTOM OF STAIR RISERS AND ADJUST RISERS AS REQ'D. - GRADE AWAY FROM FOUNDATION WALLS SHALL FALL A MINIMUM OF 6" WITHIN THE FIRST 10'. PROVIDE BLOCKING AT ALL HANDRAIL TERMINATION AND BRACKET LOCATIONS. - PROVIDE TYVEK OR EQUIVALENT HOUSE WRAP BEHIND BRICK AND STONE VENEER OVER WOOD SHEATHING. 20-MINUTE FIRE RATED DOOR BETWEEN GARAGE AND LIVING AREA. PROVIDE BRICK WEEP HOLES AT 24" O.C. WITH BRICK VENEER AND MORTER NET BEHIND AND THROUGH WEEP HOLES. EXTERIOR WALL TO BE 2x4 SPF STUD G AT 16" o.c., UNLESS OTHERWISE NOTED (10'-0" MAXIMUM UNBRACED WALL HEIGHT). - PROVIDE FLASHING AND WEEP HOLES ABOVE ALL BRICK ANGLE IRONS, BELOW ALL BRICK SILLS AND ABOVE SILL PLATE ALL EXTERIOR WALLS AND INTERIOR BEARING WALLS, FRAMED HIGHER THAN THE STANDARD PLATE HEIGHT, SHALL BE FRAMED WITH CONTINUOUS FULL HEIGHT STUDS TO THE HIGHEST CEILING (I.E. NO INTERMEDIATE BREAKS) TO PREVENT LATERAL HINGE CONDITIONS. - EXTERIOR STEPS TO HAVE A MAXIMUM 8" RISER. WHEN VERTICAL RISE EXCEEDS 30" OR FOUR OR MORE CONTINUOUS IN THE GARAGE, PROVIDE 1/2" GYP. BOARD AT ALL WALLS COMMON TO LIVING SPACE AND ALL STRUCTURAL MEMBERS SUPPORTING RISERS, A HANDRAIL IS REQUIRED FLOOR/CEILING ASSEMBLY. GARAGE CEILING TO BE 1/2" SAG RESISTANT GYP. BOARD WHEN THERE ARE NO HABITABLE SPACES ABOVE, OR 5/8" **RESIDENCE FOR:** TYPE X GYP. BOARD WHEN HABITABLE SPACES ARE ABOVE. ALL EMERGENCY ESCAPE & RESCUE OPENINGS TO BE A MAXIMUM OF 44" OFF OF FINISHED FLOOR AND HAVE MINIMUM OPENING DIMENSIONS **MARKET** OF 24" IN HEIGHT, 20" IN WIDTH, & HAVE A MINIMUM OPENING AREA OF 5.7 S.F. **ROOF PLAN NOTES** ALL DOORS TO BE 6'-8" TALL UNLESS OTHERWISE NOTED. ALL GLASS IN INTERIOR AND EXTERIOR DOORS TO BE TEMPERED (INCLUDING SIDELITES AND TRANSOMS) - ALL OVERHANGS TO HAVE (2) SOFFIT VENTS PER EACH 8' SOFFIT SECTION. ALL LUMBER CONTACTING CONCRETE TO BE PRESSURE TREATED. FOR STRUCTURE **SERENITY** - PROVIDE BAFFLES AT EXTERIOR TRUSS BEARING FOR VENTILATION. ALL FASTENERS, HANGERS, AND OTHER CONNECTORS TO BE USED WITH PRESSURE TREATED WOOD ARE TO HAVE ZMAX COATING (OR PROVIDE 15# FELT PAPER LINDER SHINGLES EQUIVALENT) HOT-DIPPED GALVANIZED OR STAINLESS STEEL. Job Number Drawina Date Coord Phone 859-578-4355 AT STAIR HANDRAIL, ON ONE SIDE ONLY, SHALL BE CONTINUOUS FOR THE ENTIRE LENGTH OF THE STAIRWAY, AND ENDS SHALL BE RETURNED TO A WALL STY5-0027-00 06/16/2022 GREG P. OR POST. THE HANDRAIL MAY BE INTERRUPTED AT A NEWEL POST AT A TURN. Drawina Scale: 1/8" = 1'0" House Name Drawn By ALL HANDRAIL GRIP PORTIONS SHALL NOT EXCEED 2-1/4" IN CROSS SECTIONAL DIMENSION. HANDRAILS SHALL BE INSTALLED ON ALL STAIRS WITH 2 OR MORE RISERS, HANDRAIL HEIGHTS SHALL BE A MINIMUM OF 34" AND A MAXIMUM OF 38". Series the EPIPHANY ALL STAIRS TO BE CONSTRUCTED SO AS NOT TO ALLOW A 4" SPHERE TO PASS THROUGH THE RISER. CLASSIC GUARDRAILS MUST BE A MINIMUM OF 36" HIGH. GUARDRAILS AT THE OPEN SIDES OF STAIRS MUST BE A MINIMUM OF 34" HIGH MEASURED VERTICALLY Plan No. FROM THE NOSING AT THE TREADS. THE HORIZONTAL SPACING OF THE VERTICAL BALUSTERS SHALL BE 4" O.C. PLAN NM - GUARDRAIL DESIGN TO RESIST A MINIMUM OF 200 LBS LATERAL FORCE

General Notes
Elevation "B"

HOMES_{sn}

Copyright © 2019, (2019) The Drees Company. All Rights Reserved. 7701 Six Forks Road, Suite 132, Raleigh, NC 27615 Phone: (919) 844-9288





RESIDENCE FOR:

MARKET


SERENITY

Job Number:	Drawing Date:	Coord Name:	Coord Phone:
STY5-0027-00	06/16/2022	GREG P.	859-578-43
House Name:	Drawi	ing Scale: 1/8" = 1'0"	Drawn By:
] <u> </u>

the **EPIPHANY**

Series: CLASSIC Plan No.: PLAN_NM





General Notes:

- 1. REFER TO SHEET ON.1 FOR GENERAL NOTES.
- 1. RETER TO SHEEL WIST FOR CHERKAL WOLDS. 2. 9-1" STANDARD PLATE HEIGHT THROUGHOUT FIRST FLOOR, UNLESS OTHERWISE NOTED. 3. 9'-1" STANDARD CEILING HEIGHT THROUGHOUT FIRST FLOOR, UNLESS OTHERWISE NOTEDFRAME TOP OF
- 3. 9'-1" STANDARD CEILING HEIGHT IHROUGHOUT FIRST FLOOR, UNLESS OTHERWISE NOTEDFRAME TOF
 4. FRAME TOP OF ALL WINDOWS AT 1'-0 1/4" BELOW TOP OF PLATE, UNLESS OTHERWISE NOTED.
- FRAME FOR OF ALL WINDOWS AT 1-0-1/4 BELOW FOR OF PLATE, UNLESS OTHERWISE NOTED.
 ALL DROPPED, INTERIOR HEADERS (FALSE AND BEARING) ARE DROPPED 1'-0" FROM CEILING.
 - 6. REFER TO SELECTION SHEETS FOR FLOORING MATERIAL PRIOR TO CONSTRUCTING STAIRS TO DETERMINE RISER HEIGHTS.
 - 7. REFER TO SHEET 2.01S FOR STRUCTURAL INFORMATION.

Key Notes:

- 201H RE: DETAIL D/7.01 FOR STAIR FRAMING DETAILS
- 201K CARPENTER TO DROP ELECTRICAL WIRE THROUGH PORCH CEILING FOR LIGHTS
- 201L PROVIDE 1/2" FIRE RATED PLYWOOD THIS SIDE
- 201M 36" HIGH SLOPED WALL WITH STAIR STRINGER
- 201N TOP OF OPENING AT 8'1" A.F.F.
- 201Q REFRIG. HEADER HELD AT 6'-1-1/2" A.F.F.

Space for Architect Seal

RESIDENCE FOR:

MARKET

SERENITY

JOD NUTIDEL.	Diawing Dule.	Coold Nulle.	Coold Hiblie.
STY5-0027-00	06/16/2022	GREG P.	859-578-43
House Name:	Drawing Scale: 1/8" = 1'0"		Drawn By:

the EPIPHANY


Series: CLASSIC
Plan No.:

PLAN_NM



2.C

First Floor Framing Plan
Elevation "B"



ONLY

SEAL

O42188

O42188

General Notes: . REFER TO SHEET SD-1 FOR ADDITIONAL ENGINEERING NOTES. Key Notes: STIA 4x4 P.T. POST W/ SIMPSON BCS2-2/4 CAP & ABW44Z BASE, (TYP.) STIC FRAME TOP OF BEAM AT 9'1" A.F.F. Space for Architect Seal

RESIDENCE FOR:

MARKET

SERENITY

Job Number:	Drawing Date:	Coord Name:	Coord Phone:
STY5-0027-00	06/16/2022	GREG P.	859-578-43
House Name:	Drawi	ing Scale: 1/8" = 1'0"	Drawn By:
			S:

the EPIPHANY

Series:

CLASSIC


Plan No.:

PLAN NM



Sheet Informatic

First Floor Structural Plan
Elevation "B"



General Notes:

- . REFER TO SHEET ON.1 FOR GENERAL NOTES.

- 2. ALL SECOND FLOOR CEILINGS TO BE 9'-1" ABOVE SUBFLOOR UNLESS OTHERWISE NOTED

 3. FRAME TOP OF ALL WINDOWS AT 1'-0 1/4" BELOW TOP OF PLATE UNLESS OTHERWISE NOTED.

 4. ALL DROPPED, INTERIOR HEADERS (FALSE AND BEARING) ARE DROPPED 1'-0" FROM CEILING UNLESS. CALCULATIONS REQUIRE LARGER HEADERS.
- 5. REFER TO SELECTION SHEETS FOR FLOORING MATERIAL PRIOR TO CONSTRUCTING STAIRS TO DETERMINE RISER HEIGHTS.
- 6. REFER TO SHEET 2.02S FOR STRUCTURAL INFORMATION...

Key Notes:

- 202A 36" HIGH WALL
- 202D A22-1/2"x32" ATTIC ACCESS
- 202I TOP OF OPENING AT 8'1" A.F.F
- 202L PROVIDE 1/2" FIRE RATED PLYWOOD THIS SIDE

Space for Architect Seal

RESIDENCE FOR:

MARKET

SERENITY


JOD NOTIFICEL.	Diawing Date.	Coold Name.	Coold Hione.
STY5-0027-00	06/16/2022	GREG P.	859-578-43
House Name:	Drawi	ng Scale: 1/8" = 1'0"	Drawn By:


the **EPIPHANY**


SSP Series: CLASSIC

Plan No.: PLAN NM









SERENITY

Job Number:	Drawing Date:	Coord Name:	Coord Phone:
STY5-0027-00	06/16/2022	GREG P.	859-578-43
House Name:	Drawi	ing Scale: 1/8" = 1'0"	Drawn By:
			١ ,

the EPIPHANY

Series:

CLASSIC


Plan No.:

PLAN_NM



2.0 Second Floor S

Second Floor Structural Plan
Elevation "B"



204D -

ROOF VENTILATION			
CITY/SERIES:	RALEIGH		
	MAIN HOUSE	GARAGE	REAR
TOTAL ATTIC AREA:	1,647	149	183
REQUIRED NET FREE VENTILATION (ATTIC AREA/300):	5.49	0.50	0.61
ACTUAL NET FREE VENTILATION (UPPER + LOWER):	5.62	0.67	1.64
DOWNSPOUT CALCULATION			
	MAIN HOUSE	GARAGE	REAR
TOTAL DRAINABLE ROOF AREA:	2141.1	193.7	237.9
MINIMUM # OF DOWNSPOUTS:	4	1	1

General Notes: . REFER TO SHEET ON.1 FOR GENERAL NOTES. Key Notes: 204A VALLEY TRUSS OVER FRAMING @ 24" O.C. 204D 4'-0"[MIN.] OF FIRE RETARDENT TREATED ROOF SHEATHING. NO PENETRATION ALLOWED WITHEN 4' OF EXTERIOR WALL - SEE DETAIL A/7.02 FOR FIRE BLOCKING AT SOFFIT Space for Architect Seal

RESIDENCE FOR:

MARKET

SERENITY


Job Number:	Drawing Date:	Coord Name:	Coord Phone:
STY5-0027-00	06/16/2022	GREG P.	859-578-43
House Name:	Drawi	ng Scale: 1/8" = 1'0"	Drawn By:
			S:
the EPI	ΡΗΔΝΥ		Series:

Plan No.:

HOMES_{SM} Copyright © 2019, (2019) The Drees Company. All Rights Reserved. 7701 Six Forks Road, Suite 132, Raleigh, NC 27615 Phone: [919] 844-9288

Elevation "B"

PLAN_NM



General Notes:

- 1. REFER TO SHEET ON.1 FOR GENERAL NOTES.
 2. FLOOR JOISTS TO BE 14" 5000 SERIES BOISE CASCADE I-JOISTS @ 19.2" o.c. UNLESS OTHERWISE NOTED.
 3. JOISTS ARE NOT TO BE PLACE DIRECTLY OVER INTERIOR PARALLEL WALL.
 [TO PREVENT UNEVEN FLOOR DEFLECTION FROM OCCURRING]
 4. ADDI JOISTS WAY BE LOCATED UP TO 2" AWAY FROM THE PARTITION WALL ABOVE IN CASES WHERE MECHANICAL PENETRATIONS

Key Notes:

302A BEARING WALL BELOW

302B BEAM BELOW - SEE SHEET 2.01S FOR MORE INFO

Space for Architect Seal

RESIDENCE FOR:

MARKET

SERENITY


Job Nullibel.	Didwing Dale.	Coold Name.	Coold Filone.
STY5-0027-00	06/16/2022	GREG P.	859-578-43
House Name:	Drawi	ing Scale: 1/8" = 1'0"	Drawn By:

the **EPIPHANY**

Series: CLASSIC

Plan No.: PLAN_NM





General Notes: . REFER TO SHEET ON.1 FOR GENERAL NOTES. Key Notes: 401A OUTLET FOR RANGE HOOD/MICROWAVE HELD HIGH - VENT TO EXTERIOR 401F DISPOSAL SWITCH AND OUTLET FOR DISHWASHER LOCATED IN SINK CABINET 401G TO SWITCH OR LIGHT ABOVE 401J A22-1/2"x32" ATTIC ACCESS MECHANICAL LEGEND ■ PHONE JACK CLG. MOUNTED LIGHT FIXT. ■ STAIR LIGHT WALL OUTLET + HOSE BIB **₹** WEATHERPROOF OUTLET SHOWER HEAD H WALL MOUNTED LIGHT FIXT. GAS GAS HOOK UP № 220 VOLT OUTLET See GROUND FAULT OUTLET - DOUBLE SPOTLIGHT FIXT. ⊕ FLOOR DRAIN FLOOR OUTLET DIRECTIONAL CAN LIGHT SD SMOKE DETECTOR © CO DETECTOR SMOKE DETECTOR/ CO DETECTOR COMBINATION ← SINGLE POLE SWITCH ₩ALL SCONCE @ 5'-6" A.F.F. ⇔ 3-WAY SWITCH FLUORESCENT LIGHT > UNDER CABINET LIGHTING EXHAUST FAN AND LIGHT COMBINATION BLOCK, MOUNT, & SWITCH FOR FUTURE FAN/LIGHT COMBINATION (CENTER, UNLESS OTHERWISE NOTED) CLG. MTD. EXHAUST FAN Space for Architect Seal

RESIDENCE FOR:

MARKET

SERENITY

| Job Number: | Drawing Date: | Coord Name: | Coord Phone: |
| STY5-0027-00 | 06/16/2022 | GREG P. | 859-578-4355 |
| House Name: | Drawing Scale: 1/8" = 1'0" | Drawn By: | SSP

the EPIPHANY

Series:

CLASSIC


Plan No.:

PLAN NM



Sheet Informa

First Floor Mechanical Plan
Elevation "B"





MARKET

SERENITY

Job Number:	Drawing Date:	Coord Name:	Coord Phone:	
STY5-0027-00	06/16/2022	GREG P.	859-578-4	135
House Name:	Drawi	ing Scale: 1/8" = 1'0"	Drawn By:	
				SS


the **EPIPHANY**


Series: CLASSIC Plan No.: PLAN NM



7701 Six Forks Road, Suite 132, Raleigh, NC 27615 Phone: [919] 844-9288

PRE-ENGINEERED WOOD TRUSSES OWNER'S HALL BATH STAIR OPENING 9'-5 1/2" KITCHEN GARAGE





the **EPIPHANY**


CLASSIC Plan No.: PLAN_NM



Building Section Elevation "B"

GABLE BRACKET D2-SMOOTH EXT. SHTG. W/ 2" TRIM @ 16" O.C. —6" CORNER TRIM 6" CORNER TRIM-6" TRIM -8" TRIM W/ TAPERED EDGE

ELEVATION "B"



TYPICAL TRIM:

6" FASCIA (ALL SIDES)

8" FRIEZE (FRONT ONLY, UNLESS OTHERWISE NOTED)

General Notes:

Key Notes:

- . REFER TO SHEET ON.1 FOR GENERAL NOTES.

1. REPER TO SHEET UN. I FUN GENERAL NOTES.
 2. ROOFING MATERIAL PER SELECTIONS.
 3. REFER TO LINITEL SCHEDULE AS NEEDED ON SHEET SD-1.
 4. CONTACT M&K ENGINEERING FOR HEADER SIZE/BRICK SUPPORT IF GRADE DROPS AND THE AMOUNT OF BRICK OVER GARAGE DOOR SHOWN ON CURRENT ELEVATION IS NO LONGER ACCURATE

Space for Architect Seal

RESIDENCE FOR:

MARKET

SERENITY

Job Number:	Drawing Date:	Coord Name:	Coord Phone:
STY5-0027-00	06/16/2022	GREG P.	859-578-43
House Name:	Drawi	ing Scale: 1/8" = 1'0"	Drawn By:
] .

the **EPIPHANY**

CLASSIC Plan No.: PLAN_NM



-4" CORNER TRIM 6" CORNER TRIM-6" TRIM-PARGED FOUNDATION 2'-0"

TYPICAL TRIM:

6" FASCIA (ALL SIDES)

FOR STRUCTURE

ONLY

8" FRIEZE (FRONT ONLY, UNLESS OTHERWISE NOTED)

General Notes:

- REFER TO SHEET ON. I FOR GENERAL NOTES.
 ROOFING MATERIAL PER SELECTIONS.
 REFER TO LINTEL SCHEDULE AS NEEDED ON SHEET SD-1.

Key Notes:

Space for Architect Seal

RESIDENCE FOR:

MARKET

SERENITY


Job Number:	Drawing Date:	Coord Name:	Coord Phone:
STY5-0027-00	06/16/2022	GREG P.	859-578-4355
House Name:	Drawi	ng Scale: 1/8" = 1'0"	Drawn By:
			SSP

the **EPIPHANY**

Series: CLASSIC Plan No.: PLAN_NM

HOMES_{SM} Garage Side Elevation Copyright © 2019, (2019) The Drees Company. All Rights Reserved. 7701 Six Forks Road, Suite 132, Raleigh, NC 27615 Phone: [919] 844-9288 Elevation "B"

	7
	4" CORNER TRIM
PARGED FOUNDATION	



General Notes: 1. REFER TO SHEET ON.1 FOR GENERAL NOTES. 2. ROOFING MATERIAL PER SELECTIONS. 3. REFER TO LINTEL SCHEDULE AS NEEDED ON SHEET SD-1.

Key Notes:

Space for Architect Seal

TYPICAL TRIM:

6" FASCIA (ALL SIDES)

8" FRIEZE (FRONT ONLY, UNLESS OTHERWISE NOTED)

RESIDENCE FOR:

MARKET

SERENITY

the EPIPHANY

Series:

CLASSIC

Plan No.:


PLAN_NM



Sheet Informatiic

Rear Elevation
Elevation "B"


—6" CORNER TRI 4" CORNER TRIM-PARGED FOUNDATION 2'-0"



TYPICAL TRIM:

6" FASCIA (ALL SIDES)


8" FRIEZE (FRONT ONLY, UNLESS OTHERWISE NOTED)





HOMES_{SM}

Elevation "B"

Copyright © 2019, (2019) The Drees Company. All Rights Reserved. 7701 Six Forks Road, Suite 132, Raleigh, NC 27615 Phone: [919] 844-9288










SOFFIT FIRE BLOCKING DETAILS

SCALE: 1/4" = 1"-0"





A" CORNER TRIM————————————————————————————————————		12 8
	4" CORNER TRIM─── -	6" CORNER TRIM
PARGED FOUNDATION		



TYPICAL TRIM:

6" FASCIA (ALL SIDES)

8" FRIEZE (FRONT ONLY, UNLESS OTHERWISE NOTED)





Job Number:	Drawing Date:	Coord Name:	Coord Phone:	
STY5-0027-00	06/16/2022	GREG P.	859-578-	435
House Name:	Drawi	ing Scale: 1/8" = 1'0"	Drawn By:	
				SS


the **EPIPHANY**

Series: CLASSIC Plan No.: PLAN_NM











SOFFIT FIRE BLOCKING DETAILS

SCALE: 1/4" = 1"-0"





CONNECTION SPECIFICATIONS (TYP. U.N.O.)

NOTE: 10d NAIL = 3" x 0.131" GUN NAIL					
JOIST TO SOLE PLATE	(3)10d TOENAILS				
SOLE PLATE TO JOIST/BLK'G. STUD TO SOLE PLATE	10d NAILS @ 6" o.c. (3)10d TOENAILS				
TOP OR SOLE PLATE TO STUD	(3)10d NAILS				
RIM TO TOP PLATE	10d TOENAILS @ 6" o.c.				
BLK'G. BTWN. JOISTS TO TOP PL.	(3)10d TOENAILS				
RAFTER/TRUSS TO TOP PLATE	(3)10d TOENAILS +				
	(I) SIMPSON H2.5A				
GAB. END TRUSS TO DBL. TOP PL.	10d TOENAILS @ 8" o.c.				
R.T. w/ HEEL HT. 9 1/4" TO 12"	2xIO BLK EVERY 3RD BAY FASTENED TO DBL. TOP PLATE w/ IOd TOENAILS @ 6" O.C.				
R.T. w/ HEEL HT. 12" TO 16"	2xI2 BLK EVERY 3RD BAY FASTENED TO DBL. TOP PLATE w/ IOd TOENAILS @ 6" O.C.				
R.T. w/ HEEL HT. UP TO 24"	LAP WALL SHTG. W/ DBL. TOP PL. & INSTALL ON TRUSS VERT FASTEN W/ 8d NAILS @ 6" O.C.				
R.T. w/ HEEL HT. 24" TO 48"	LAP WALL SHTG. W/ DBL. TOP PL. & INSTALL ON TRUSS VERT FASTEN W/ 8d NAILS @ 6" O.C. PROVIDE 2x BLK @ EA. BAY AT TOP OF HEEL				
DOUBLE STUD	10d NAILS @ 24" o.c.				
DOUBLE TOP PLATE	10d NAILS @ 24" o.c.				
DOUBLE TOP PLATE LAP SPLICE	(10)10d NAILS IN LAPPED AREA				
TOP PLATE LAP @ CORNERS & INTERSECTING WALLS	(2)10d NAILS				
WALL TO FOUNDATION	WALL SHTG. LAP W/ SILL PL. & FASTENED PER SHEAR WALL FASTENING SPEC.				

GARAGE SLAB

4" CONC. SLAB w/ 6x6-WI.4xWI.4 WWF ON 6 MIL VAPOR BARRIER ON 4" MIN. GRANULAR FILL ON 95% COMPACTED FILL/VIRGIN SOIL

PORCH SLAB

4" CONC. SLAB W/ 6x6-WI.4xWI.4 WMF ON 95% COMPACTED FILL/VIRGIN SOIL

BASEMENT SLAB 4" CONC. SLAB ON 6 MIL VAPOR BARRIER

ON 4" MIN. GRANULAR FILL ON 95% COMPACTED FILL/VIRGIN SOIL

SLAB ON GRADE

4" CONC. SLAB w/ 6x6-WI.4xWI.4 WWF ON 6 MIL VAPOR BARRIER ON 4" MIN. GRANULAR FILL ON 95% COMPACTED FILL/VIRGIN SOIL

VENEER LINTEL SCHEDULE

SPAN (MAX)	HEIGHT OF VENEER ABOVE LINTEL	STEEL ANGLE SIZE
3'-0"	20 FT. MAX	L3"x3"x¼"
	3 FT. MAX	L3"x3"x¼4"
6'-0"	I2 FT. MAX	L4"x3"x¼"
	20 FT. MAX	L5"x3½"x516"
8'-0"	3 FT. MAX	L4"x4"x/4" *
0-0	I2 FT. MAX	L5"x3½"x5%"
	16 FT. MAX	L6"x31/2"x3/6"
9'-6"	I2 FT. MAX	L6"x31/2"x5/6"
16'-0"	2 FT. MAX	L7"x4"x½" **
	3 FT. MAX	L8"x4"x½" **

- SHALL SUPPORT 2 5/6" - 3 1/2" VENEER W/ 40 psf MAXIMUM WEIGHT. < 16' SHALL HAVE 4" MIN. BEARING

- = 16' SHALL HAVE 8" MIN. BEARING < 16' SHALL NOT BE FASTENED BACK TO HEADER. = 16' SHALL BE FASTENED BACK TO WOOD HEADER IN WALL @48"o.c. w/½" DIA. x 3, LONG LAG SCREMS IN 2" LONG VERTICALLY SLOTTED HOLES.

 MAX. VENEER HT. APPLIES TO ANY PORTION OF BRICK OVER THE OPENING. ALL LINTELS SHALL BE LONG LEG VERTICAL.
- WHEN SUPPORTING VENEER < 3" WIDE THE EXTERIOR TOE OF THE HORIZONTAL LEG MAY BE CUT IN THE FIELD TO BE 3 $\frac{1}{4}$ " WIDE OVER THE BEARING LENGTH ONLY. THIS IS TO ALLOW FOR MORTAR JOINT FINISHING SEE STRUCTURAL PLANS FOR ANY LINTEL CONDITION NOT ENCOMPASSED BY THE FOR QUEEN VENEER USE L4x3x1/4"

* FOR 3½" VENEER ONLY. SEE PLAN FOR VENEER SUPPORT IF VENEER < 3½" THICK.

LEGEND

- IIIIIIII INTERIOR BEARING WALL
- BEARING WALL ABOVE BEAM / HEADER
- EXTENT OF OVERFRAMING
 - METAL HANGER
- - INDICATES EXTENT OF INT. OSB SHEARWALL, BLOCKED PANEL EDGES, AND/OR 3" O.C. EDGE NAILING
- INDICATES HOLDOWN
- INDICATES POST ABOVE (P.A.) PROVIDE SOLID BLOCKING UNDER POST OR JAMB ABOVE.

ADDITIONAL NOTES FOR TRUSS & -JOIST MANUFACTURER

ROOF TRUSS, FLOOR TRUSS AND ENGINEERED JOISTS SHALL BE DESIGNED TO MEET THE DEFLECTION CRITERIA BELOW, UNLESS NOTED OTHERWISE ON PLAN. MULHERN & KULP CANNOT BE HELD RESPONSIBLE FOR ANY STRUCTURAL ISSUES RELATED TO ANY BUILDING COMPONENT IF COMPONENT SHOP DRAWINGS ARE NOT SUBMITTED TO M&K FOR REVIEW PRIOR TO FABRICATION, DELIVERY, OR INSTALLATION.

TRUSSES/JOISTS SHALL BE DESIGNED SO THAT DIFFERENTIAL DEFLECTION BETWEEN ADJACENT PARALLEL TRUSSES/JOISTS OR GIRDER TRUSSES/FLUSH BEAMS DO NOT EXCEED THE FOLLOWING:

- 4. ROOF TRUSSES: 1/4" DEAD LOAD
- B. FLOOR TRUSSES, ATTIC TRUSSES, & I-JOISTS: 1/8" DEAD LOAD
- ABSOLUTE DEAD LOAD DEFECTION OF FLOOR TRUSSES/ATTIC TRUSSES WHEN ADJACENT TO FLOOR FRAMING BY OTHERS SHALL BE LIMITED TO 3/16". (NOT DIFFERENTIAL DEFLECTION)

GENERAL STRUCTURAL NOTES

FOUNDATION

- DESIGN IS BASED ON 2019 OHIO RESIDENTIAL CODE.
- FOOTING DESIGN 1,500 PSF NET ALLOWABLE SOIL BEARING PRESSURE IS ASSUMED. BUILDER/CONTRACTOR MUST VERIFY.
- FASTEN 2x6 SILL PLATES TO CONC FND WITH A MINIMUM OF 2 ANCHORS PER PLATE, 12" MAX. FROM PLATE ENDS - UTILIZING:
- 1/2" DIA. ANCHOR BOLTS @ 6'-0" O.C,7" MIN. EMBEDMENT • SIMPSON MAB STRAPS @ 32" O.C.
- SIMPSON MASA ANCHOR STRAPS @ 6'-0" O.C. • ALL LUMBER EXPOSED TO WEATHER OR IN CONTACT W/ PERIMETER
- FOUNDATION SHALL BE PRESERVATIVE TREATED SOUTHERN PINE #2. • BUILDER TO VERIFY CORROSION-RESISTANCE COMPATIBILITY OF HARDWARE & FASTENERS IN CONTACT W/ PRESERVATIVE-TREATED
- FOUNDATION WALLS & FOOTINGS SHALL BE PLAIN CONCRETE, U.N.O

WOOD. CONTACT LUMBER & HARDWARE SUPPLIERS TO COORD.

- ONCRETE DESIGN BASED ON ACI 318. CONCRETE SHALL ATTAIN THE FOLLOWING MIN. COMPRESSIVE STRENGTHS IN 28 DAYS, U.N.O. f'c = 4,000 psi: FOUNDATION WALLS
- 3,000 psi: FOOTINGS & INTERIOR SLABS ON GRADE 3,500 psi: GARAGE & EXTERIOR SLABS ON GRADE fy = 60,000 psi
- BASEMENT FOUNDATION WALL DESIGN BASED ON: 8' OR 9' HEIGHT (AS NOTED ON PLANS)
 - TALLER WALLS MUST BE ENGINEERED.
- NOMINAL WIDTH (8" FOR 8' WALL, 10" FOR 10' WALL).
- BASEMENT WALL DESIGN IS BASED ON 30 OR 45 PCF BACKFILL SOIL TYPE CLASSIFICATIONS:
- 30 PCF TYPE (GW, GP, SW, SP) 45 PCF TYPE (GM, GC, SM, SM-SC, ML)
- IMPORTANT IF 60 PCF SOIL TYPE (SC, ML-CL, OR CL) IS UTILIZED FOR BACKFILL, CONTACT MULHERN & KULP FOR FURTHER EVALUATION OF FOUNDATION DESIGN.
- BASEMENT WALLS SHALL BE BRACED, PRIOR TO BACKFILLING, BY ADEQUATE TEMPORARY BRACING OR INSTALL IST FLOOR DECK.
- PROVIDE (2) #5 BARS AROUND ALL SIDES OF OPENINGS IN CONCRETE BSMT. FND. WALL WITH 2" CLEAR. REINFORCEMENT SHALL EXTEND 12" PAST CORNER OF OPENING IN ALL DIRECTIONS
- FOR OPENINGS UP TO 36", PROVIDE MINIMUM 10" CONCRETE DEPTH OVER OPENING OR (3)2x10 w/(2)2x6 JACK STUDS, U.N.O. • LARGER OPENINGS SHALL BE PER PLAN.
- ALL CONCRETE EXPOSED TO THE WEATHER SHALL NOT HAVE LESS THAN 5% OR MORE THAN 7% AIR ENTRAINMENT.
- ALL FOOTINGS SHALL BEAR BELOW FROST LINE (TYP.) OR 12" MIN IN REGIONS WHERE CODE FROST DEPTH IS NOT APPLICABLE. CONSULT SOILS REPORT OR BUILDING DEPT. FOR MINIMUM DEPTH BELOW GRADE.
- FOOTINGS AND SLABS ON GRADE SHALL BEAR ON VIRGIN SOIL OR 95% COMPACTED FILL.
- PROVIDE CONTROL JOINTS AT ALL INSIDE CORNERS OF SLAB EDGES, AND OTHER LOCATIONS WHERE SLAB CRACKS ARE LIKELY TO DEVELOP.
- JOINTS SHALL BE LOCATED @ 10'-0" O.C. (RECOMMENDED) OR 15'-0" O.C. (MAXIMUM)
- JOINT GRID PATTERN SHALL BE AS CLOSE TO SQUARES AS POSSIBLE (I:I RATIO), WITH A MAXIMUM OF I:I.5 RATIO • CONTROL JOINTS SHALL <u>NOT</u> BE INSTALLED IN STRUCTURAL SLABS
- TYPICAL REINFORCEMENT DETAILS: PROVIDE 3" MIN. CLEAR COVER WHERE CAST AGAINST EARTH, I 1/2" MIN. CLEAR COVER AGAINST FORMS. LAP ALL REBAR 48 BAR DIAMETERS MIN. (24" FOR #4 BARS) & BEND BARS AND LAP AT CORNERS. PROVIDE 6" HOOK INTO SUPPORTING FOOTINGS WHEN FOOTINGS INTERSECT.
- DIMENSIONS BY OTHERS, BUILDER TO VERIFY. M&K STND. - MAY 2012

LATERAL/WALL BRACING & WALL SHEATHING SPECIFICATIONS

THIS MODEL HAS BEEN DESIGNED TO RESIST LATERAL FORCES RESULTING FROM:

120 MPH WIND IN 2018 NGSBC (120 MPH WIND SPEED IN ASCE 7-10

WIND MAP, PER IRC R301.2.1.1) EXP. B & SEISMIC CAT. A/B.

EXT. WALL SHEATHING SPECIFICATION

- 7/16" OSB OR 15/32" PLYWOOD: FASTEN SHEATHING w/ 2 3 x0.113 NAILS @ 6" O.C. AT EDGES & @ 12" O.C. IN THE PANEL FIELD. (TYP, U.N.O.,
- ALL SHEATHING PANELS SHALL BE ORIENTED VERTICALLY (LONG DIRECTION PARALLEL TO STUDS) AND INSTALLED FULL HEIGHT OF SHEAR WALL - OR -2x HORIZONTAL BLOCKING SHALL BE PROVIDED TO SUPPORT ALL UNSUPPORTED PANEL EDGES & EDGE FASTENING.
- ALL EXT. WALLS SHALL BE CONTINUOUSLY SHEATHED AND ARE CONSIDERED SHEAR WALLS.
- ALT. STAPLE CONNECTION SPEC: 1 3/4" 16 GA STAPLES (1/6" CROWN) @ 3" O.C. AT EDGES € @ 6" O.C IN FIELD.

3" O.C. EDGE NAILING

• AT DESIGNATED AREAS - FASTEN PANEL EDGES OF WOOD STRUCTURAL WALL SHEATHING TO FRAMING W/ 2 3 × 0.113 NAILS @ 3 O.C. AND 12 O.C. IN THE PANEL FIELD NO STAPLE ALTERNATIVE AVAILABLE AT THIS SPEC. ALL SHEATHING PANELS SHALL BE ORIENTED VERTICALLY (LONG DIRECTION PARALLEL TO STUD) AND INSTALLED FULL HEIGHT OF SHEAR WALL - OR - 2x HORIZONTAL BLOCKING SHALL BE PROVIDED TO SUPPORT UNSUPPORTED PANEL EDGES AND 3" O.C. EDGE FASTENING.

- SEE CONNECTION SPECIFICATIONS CHART FOR STANDARD SHEAR TRANSFER DETAILING. IF ADDITIONAL CAPACITY IS REQUIRED BY DESIGN, IT WILL BE SPECIFICALLY NOTED ON PLAN.
- DESIGN ASSUMES I6" O.C MAX. STUD SPACING, U.N.O.
- ALL STRUCTURAL PANELS ARE TO BE DIRECTLY APPLIED TO STUD FRAMING.
- PRE-MANUFACTURED PANELIZED WALLS: FASTEN TOGETHER END STUDS OF WALL PANELS SHEATHED W/ OSB OR PLYWOOD W/ IOd NAILS @ 4" O.C. (THRU ONE SIDE ONLY)

INDICATES EXTENT OF INT. OSB SHEARWALL, BLOCKED PANEL EDGES, AND/OR 3" O.C. EDGE NAILING



* INDICATES POST ABOVE (P.A.) PROVIDE SOLID BLOCKING UNDER POST OR JAMB ABOVE.

M&K STND. - SEPT. 2018

GENERAL STRUCTURAL NOTES

FLOOR FRAMING

- I-JOISTS/TRUSSES SHALL BE DESIGNED BY MANUF. TO MEET OR EXCEED L/480 LIVE LOAD DEFLECTION CRITERIA. (EXCLUDES STONE/MARBLE OR WET BED CONSTRUCTED FLOORS - CONTACT M&K FOR EXCLUDED FLOOR DESIGNS)
- PER THE GUIDELINES OF THE TILE COUNCIL OF NORTH AMERICA (TCNA HANDBOOK), IT SHALL BE THE FLOOR FINISH INSTALLER'S RESPONSIBILITY TO VERIFY THAT THE FINISHES TO BE INSTALLED MATCH THE DESIGN CRITERIA NOTED ABOVE (UNDER "DESIGN LOADS").
- AT I-JOIST FLOORS, PROVIDE I 1/8" MIN. OSB RIM BOARD.
- METAL HANGERS SHALL BE SPECIFIED BY MANUFACTURER, U.N.O.
- $\mid ullet \mid$ I-JOIST/TRUSS SHOP DWGS. SHALL BE SUBMITTED TO ARCH. & ENG. FOR REVIEW AND APPROVAL PRIOR TO FABRICATION OR DELIVERY.
- FLOOR SHEATHING SHALL BE 23/32" A.P.A. RATED 'STURD-I-FLOOR' 24" O.C., EXPOSURE I (OR APPROVED EQUAL) WITH TONGUE AND GROOVE EDGES. FASTEN TO FRAMING MEMBERS W/ GLUE AND
- 2 ½" x 0.131" NAILS @ 6"o.c. @ PANEL EDGES & @ 12"o.c. FIELD. - 2 훍" x 0.120" NAILS @ 4" O.C. @ PANEL EDGES & @ 8" O.C. FIELD.

- 2 3 × 0.113 NAILS @ 3" O.C. @ PANEL EDGES & @ 6" O.C. IN FIELD.

ROOF FRAMING


- ROOF SHEATHING SHALL BE 7/16" A.P.A. RATED SHEATHING 24/16 EXPOSURE I (OR APPROVED EQUAL). FASTEN TO FRAMING MEMBERS - w/ 2 ½" x 0.131" NAILS @ 6"o.c. @ PANEL EDGES & @ 12" O.C. FIELD. - w/ 2 3/8 × 0.120" NAILS @ 4"o.c. @ PANEL EDGES \$ @ 8" O.C. FIELD. - W/ 2 3 × 0.113 NAILS @ 3 o.c. @ PANEL EDGES € @ 6 O.C. FIELD.
- WITHIN 48" OF ALL ROOF EDGES, RIDGES, & HIPS FASTEN ROOF SHEATHING FIELDS PER EDGE NAILING SPEC.
- FASTEN EACH ROOF TRUSS TO TOP PLATE W/ SIMPSON H2.5A CLIP (OR APPROVED EQUAL) @ ALL BEARING POINTS. PROVIDE (2) H2.5A CLIPS AT 2-PLY GIRDER TRUSSES, (3) H2.5A CLIPS AT 3-PLY GIRDER TRUSSES & ROOF BEAMS - AT ALL BEARING POINTS.
- METAL HANGERS SHALL BE SPECIFIED BY THE MANUFACTURER, U.N.O. • ROOF TRUSS SHOP DWGS. SHALL BE SUBMITTED TO ARCH & ENG. FOR REVIEW AND APPROVAL PRIOR TO FABRICATION OR DELIVERY.
- ERECT AND INSTALL ROOF TRUSSES PER WTCA & TPI'S BCSI I "GUIDE TO GOOD PRACTICE FOR HANDLING, INSTALLING & BRACING OF METAL PLATE CONNECTED WOOD TRUSSES."
- SUPPORT SHORT SPAN ROOF TRUSSES W/2x4 LEDGER FASTENED TO FRAMING w/(2) 3" x 0.120" NAILS @ 16" O.C. (UP TO 7' SPAN).

M&K STND. - MAR 2016

MULHERN+KULP RESIDENTIAL STRUCTURAL ENGINEERING

p 215-646-8001 ► *mulhemkulp.com*

300 Brookside Ave, Building 4 ► Ambler, PA 19002



● DESIGN IS BASED ON 2018 NORTH CAROLINA RESIDENTIAL CODE.

GENERAL STRUCTURAL NOTES

- WOOD FRAME ENGINEERING IS BASED ON NDS, "NATIONAL DESIGN SPECIFICATION FOR WOOD CONSTRUCTION" - LATEST EDITION.
- DESIGN LOADS:

ROOF LIVE = 20 PSF (18 PSF REDUCED) DEAD = 7 PSF T.C., 10 PSF B.C. LOAD DURATION FACTOR = 1.15

FLOOR LIVE = 40 PSF (30 PSF @ SLEEPING AREAS) DEAD = 10 PSF (I-JOISTS & SOLID SAWN) ADD'L IO PSF @ CERAMIC TILE IN KITCHEN, BATHS, SUNROOM, & LAUND.

1,500 PSF ASSUMED ALLOWABLE BEARING PRESSURE (TO BE VERIFIED BY BUILDER)

GENERAL FRAMING

- ALL TYP. NAIL FASTENER REQUIREMENTS ARE NOTED IN STANDARD CONNECTIONS TABLE (IRC TABLE R602.3(I)) OR ON PLANS. ALL NAILS SPECIFIED ARE MIN DIAMETER AND LENGTH REQUIRED FOR CONNECTION. ALL HANGER NAILS SHALL BE INSTALLED PER MANUFACTURER'S REQUIREMENTS FOR MAX CHARTED CAPACITY. NOTE: HANGERS USE COMMON NAIL DIAMETERS NOT TYPICAL FRAMING GUN NAILS.
- PEXT. & INT. BEARING WALLS SHALL BE 2x4 OR 2x6 (AS SHOWN ON PLANS) @ 16" O.C. SPF "STUD" GRADE LUMBER, OR BETTER, U.N.O. • WALLS OVER 10' TALL SHALL BE PER PLAN.
- ALL INTERIOR BEARING WALLS ARE ASSUMED TO BE SHEATHED W/ GYP WALL BOARD (ONE SIDE MIN.) OR PROVIDE MID HT. BLOCKING.
- ALL 2x8, 2x10, & 2x12 HEADERS, BEAMS & OTHER STRUCTURAL MEMBERS SHALL BE S.Y.P. #2 LUMBER, OR BETTER. ALL 2x6 HEADERS, BEAMS & OTHER STRUCTURAL MEMBERS SHALL
- BE SPF "STUD" GRADE LUMBER, OR BETTER. • SUPPORT ALL HEADERS/ BEAMS W/ (1)2x JACK STUD & (1)2x KING
- THE NUMBER OF STUDS SPECIFIED AT A SUPPORT INDICATES THE NUMBER OF JACK STUDS REQUIRED, U.N.O..
- ALL NON-BEARING INTERIOR STUD WALLS SHALL BE CONSTRUCTED WITH 2x 'STUD' GRADE MEMBERS SPACED @ 24" O.C. (MAX., U.N.O.) • HEADERS IN NON-LOAD BEARING WALLS SHALL BE:
- (1)2x4/6 FLAT @ OPENINGS UP TO 4', (2)2x4/6 FLAT UP TO 8'.
- ' ALL FRAMING LUMBER SHALL BE DRIED TO 15% MC (KD-15). PENGINEERED LUMBER BEAMS TO MEET OR EXCEED THE FOLLOWING: 'LSL' - Fb=2325 psi; Fv=310 psi; E=1.55x10^6 psi
- 'LVL' Fb=2600 psi; Fv=285 psi; E=2.0x10^6 psi PENGINEERED LUMBER POSTS TO MEET OR EXCEED THE FOLLOWING: 'LVL' - Fb=2400 psi; FcII=2500 psi; E=1.8xI0^6 psi
- FOR 2 & 3 PLY BEAMS OF EQUAL 13/4" MAX. WIDTH, FASTEN PLIES TOGETHER WITH 3 ROWS OF 3"XO.120" NAILS @ 8" O/C OR 2 ROWS 1/4"x3/5" SIMPSON SDS SCREWS (OR 3/5" TRUSSLOK SCREWS) @ 16" O/C. USE A MINIMUM OF 4 ROWS FOR BEAM DEPTHS OF 14" OR GREATER. APPLY FASTENING AT BOTH FACES FOR 3-PLY CONDITION. LOCATE TOP & BOTTOM NAILS/SCREWS 2" FROM EDGE SOLID 3 ½" OR 5 ¼" BEAMS ARE ACCEPTABLE. USE 2 ROWS OF NAILS FOR 2x6 \$ 2x8 MEMBERS.
- FOR 4 PLY BEAMS OF EQUAL 13/4" MAX. WIDTH, FASTEN PLIES TOGETHER WITH 3 ROWS OF 1/4"x6" SIMPSON SDS SCREWS (OR 6 3/4" TRUSSLOK SCREWS) @ 16" O/C. USE A MINIMUM OF 4 ROWS FOR BEAM DEPTHS OF 14" OR GREATER. APPLY FASTENING AT BOTH FACES (ONE SIDE ONLY FOR TRUSSLOK SCREWS). LOCATE TOP AND BOTTOM SCREWS 2" FROM EDGE. A SOLID 7" BEAM IS ACCEPTABLE.
- PROVIDE SOLID BLOCKING IN FLOOR SYSTEM UNDER ALL POSTS CONTINUOUS TO FND./BEARING. BLOCKING TO MATCH POST ABOVE.
- FASTEN 2x WOOD PLATES TO TOP FLANGE OF STEEL BEAMS WITH P.A.F.'s ('HILTI' XU PINS OR EQUAL) @ 16" O.C. STAGGERED, OR I/2" DIA. BOLTS @ 48" O.C. STAGGERED.
- STEEL PIPE COLUMN "ASD CAPACITIES" SHALL MEET OR EXCEED THE LOADS PROVIDED AT EACH STEEL PIPE COLUMN LOCATION ON PLAN. COLUMNS ARE TO BE INSTALLED PER THE MANUFACTURER'S REQUIREMENT THAT ACHIEVES THE RATED CAPACITY USED, INCLUDING BUT NOT LIMITED TO POSITIVE CONNECTIONS AT THE TOP AND BOTTOM OF THE COLUMN. TWO COLUMNS MAY BE USED UNDER CONTINUOUS BEAMS TO ACHIEVE THE FULL PLAN SPECIFIED REQUIRED CAPACITY IF INSTALLED CENTERED ON THE EXISTING FOOTING/ PLAN SPECIFIED SINGLE COLUMN LOCATION.

Structural Engineering, Inc.

Mulhern+Kulp project number:

BSM project mgr: CNV drawn by: 08-16-22 issue date:


REVISIONS:

initial:

HER



SD-



SHEAR TRANSFER DETAIL BETWEEN FLOORS @ CANT'D EXT. WALL SCALE: 3/4"=1'-0" PERPENDICA PERPENDICULAR FRAMING

(SEE PLAN) TYPICAL SHEAR TRANSFER DETAIL BETWEEN FLOORS @ INTERIOR WALL

SCALE: 3/4"=1'-0"

FASTEN 2x6 LEDGER OR TOP

CHORD OF TRUSS TO TO EA.

SHEARWALL TO RIM BOARD W/

3"x0.131" NAILS @ 6" O.C. OR

3"x0.120" NAILS @ 4" O.C.

STUD w/ (3) 3"x0.131" NAILS

OR (3) 3"x0.l20" NAILS

WALL ABOVE

LI-JOISTS

(SEE PLAN)

copyright : MULHERN & KULP Structural Engineering, Inc.

> HOME DREE

Mulhern+Kulp project number:

BSM project mgr: CNV drawn by: 08-16-22 issue date:

REVISIONS:


initial:


RESIDENTIAL STRUCT
3625 Brookside Parkway, Suite 1
p 779-777-9674 > mathemicalpus


EPIPHANY MODEL STY5-0027


LATERAL DETAILS


SD-2

















ALL COLUMN SURFACES TO BE PAINTED TRIM GLOSS COLOR, UNLESS NOTED OTHERWISE.



DETAIL W/ WALL ABOVE (TYP.)








COLUMN DETAIL (INTERIOR)

DRYWALL

FINISH

PLAN

STANDARD



SCALE: 1/2" = 1'-0"

Drees Homes

7701 Six Forks Road, Suite 132, Raleigh, NC 27615 PH:(919) 844-9288 Copyright ©, 2005 The Drees Company, All rights reserved. These plans are protected by Copyright. No part of these plans may be reproduced in any form or by any means, including photocopying, without the written permission from the Copyright owner.

STD. DETAIL SHEE RALEIGH Std. Date: 9/18/09

DRYWALL

FINISH

<u>PLAN</u>

STANDARD W/ CRAFTSMAN PACKAGE

> Sheet Description: COLUMN DETAILS SUNROOM DETAILS

DETAILS MAY NOT APPLY TO CONTRACT

Sheet No.

-1x4 ROUGH

SAWN TRIM

-1x6 ROUGH

___ SAWN TRIM

(STAINED)

(PER SPECS)

(STAINED)

SAWN TRIM

1x6 ROUGH

→ SAWN TRIM

(STAINED)

SLAT SHUTTER DETAIL

1'-4" SINGLE TRAY

D2.4 SCALE: 1/2" = 1'-0"

JOIST

CEILING DETAIL

→ DRYWALL` - CROWN MOULD (PER SPEC\$)


SCALE: 1/4" = 1'-0"

(STAINED)



ARC 10.11.06

RALEIGH - D-SHEETS.dwg Mar 24, 2015 - 12:15pm



Drees

Drees Homes 7701 Six Forks Road, Suite 132, Roleigh, NC 27615 PH:(919) 844-9288

Copyright ©, 2005 The Drees Company, All rights reserved. These plans are protected by Copyright. No part of these plans may be reproduced in any form or by any means, including photocopying, without the written permission from the Copyright owner.

STD. DETAIL SHEET | Sid. By: DWW | Chk. By: ARC | Std. Dote: 1.9.07 | Chg. Rev. 02/28/08 bdt | C


Sheet Description:


INTERIOR TRIM DETAILS DETAILS MAY NOT APPLY TO CONTRACT


D2.5

Sheet No.


RALEIGH - D-SHEETS.dwg Dec 10, 2014 - 1:50pm







Note: Ceiling treatment details will tray down into space on enclosed rooms located on the 1st floor. On enclosed rooms on the 2nd floor, the ceiling treatment will tray up into the roof truss system. On 2-story spaces, the ceiling treatment will tray down into the space and require an appropriate sized header to capture the ceiling detail return.



-8x8 BOX BEAM


1st floor. On enclosed rooms on the 2nd floor, the ceiling treatment will tray up into the roof truss system. On 2-story spaces, the ceiling treatment will tray down into the space and require an appropriate sized header to capture the ceiling detail return.

Note: Ceiling treatment details will tray down into space on enclosed rooms located on the

DATE OF DETAIL:

5-1/4" CROWN MOULD 5/8"x3/4" BASE MOULD


SECTION




TYPICAL PLAN



Note: Ceiling treatment details will tray down into space on enclosed rooms located on the 1st floor. On enclosed rooms on the 2nd floor, the ceiling treatment will tray up into the roof truss system. On 2-story spaces, the ceiling treatment will tray down into the space and require an appropriate sized header to capture the ceiling detail return.



TYPICAL PLAN





DETAIL


Note: Ceiling treatment details will tray down into space on enclosed rooms located on the 1st floor. On enclosed rooms on the 2nd floor, the ceiling treatment will tray up into the roof truss system. On 2-story spaces, the ceiling treatment will tray down into the space and require an appropriate sized header to capture the ceiling detail return.


CEILING TREATMENTS

SCALE: AS NOTED











FIREPLACE DOGHOUSE SECTIONS

SCALE: 1/4" = 1'-0"



DIRECT VENT REAR WALL FRAMING



NOTE: PROVIDE OSB SHEATHING WHEN STONE VENEER SELECTED

FIREPLACE ROUGH OPENING SCHEDULE								
FIDEDI A CE LA NILIE A CTUDED	MODEL	A	В	С	D			
FIREPLACE MANUFACTURER		(FIREBOX REQUIRED WIDTH)	(FIREBOX REQUIRED HEIGHT) *ADD 18" W/ OPT. HEARTH	(FIREBOX REQUIRED DEPTH - INTERIOR REAR WALL TO FRONT EXTERIOR WALL)	(VENT CENTERLINE HEIGHT) *ADD 18" W/ OPT. HEARTH			
	SLIMLINE SL-7	42"	38-1/4"	16-1/4"	TOP 40" SIDE 26-7/8"			
HEAT & GLO	COSMO 42	49"	32-3/4"	17-3/4"	TOP ONLY 47-1/16"			
	COURTYARD 36	43-3/8"	44-1/8"	18-3/8"	SEE MANUFACTURER'S SPEC			
HEARTH & HOME	COURTYARD 42	49-1/4"	44-1/8"	18-1/8"	SEE MANUFACTURER'S SPEC			
	LANAI *(NOT IN CINCY/NKY)	57-3/4"	39-1/2"	17-5/8"	SEE MANUFACTURER'S SPEC			
	RAVE	50"	40-1/4"	18-1/4"	TOP ONLY 46-1/2"			
			all dimensions	are in inches				

General Notes

REFER TO SHEET ON.1 FOR GENERAL NOTES.
 VERIFY FIREPLACE MODEL AND HEARTH SELECTION WITH CUSTOMER'S SELECTIONS.

Key Notes

1 FUTURE FRAMING FOR F.P. OPENING AFTER INSULATION HAS BEEN INSTALLED IN EXT. WALL:

2 FLASHING

3 HEADER PER PLAN

4

5 1" AIRSPACE

6 BOX OUT FOR FLUE (REFER TO SELECTIONS FOR FIREPLACE AND OPENING HEIGHT)

HOMES.

The Drees Company
211 Grandview Drive Fort Mitchell, Kentucky 41017 PH;(859) 578-4200

Copyright © 2021, (2021) The Drees Company. All Rights Reserved. No portion of this material may be reproduced in any form or by any means, including photocopying, without the express written permission of the Drees Company. The Drees Company will vigorously prosecute any unauthorized use of this material.

FIREPLACE DETAILS

Std. Drawn By:	MRPH	Sheet Description:	SCALE: VARIES		
		FIREPLACE DETAIL			
Std. Date:	02.29.20				
Date of Last Rev:	7.21.2021	2021 g:\architecture\cincinnati\cinti standard drawings\fireplace\text{direplace detail sheets.dwg}			

Sheet No.

F-1

RALEIGH WINDOW SCHEDULE

* MEETS EMERGENCY ESCAPE & RESCUE OPENING REQUIREMENTS

		MI Windows	and Doors			T				OPENING REQUIREMENTS
Drees General Callout	Window Type	Capitol Call No.	Series Rough Opening	Call No.	Rough Opening	Drees General Callout	Call No.	Rough Opening	Call No.	Rough Opening
1660	SINGLE/DOUBLE HUNG	CW3500 1/8 x 6/0	1	Call No.	Rough Opening		Call No.	Kough Opening	Call No.	Kough Opening
1670	SINGLE/DOUBLE HUNG	CW3500 1/8 x 7/0	20" x 84"							
1860	SINGLE/DOUBLE HUNG	CW3500 1/8 x 6/0	20" x 60-1/4"							
2030 2040	SINGLE/DOUBLE HUNG SINGLE/DOUBLE HUNG	CW3500 2/0 x 3/0 CW3500 2/0 x 4/0	24 X 36 24" x 48"							
2050	SINGLE/DOUBLE HUNG	CW3500 2/0 x 5/0	24" x 60-1/4"							
2060	SINGLE/DOUBLE HUNG	CW3500 2/0 x 6/0	24" x 72"							
2070 2430	SINGLE/DOUBLE HUNG SINGLE/DOUBLE HUNG	CW3500 2/0 x 7/0 CW3500 2/4 x 3/0	24" X 84" 28" × 36"							
2440	SINGLE/DOUBLE HUNG	CW3500 2/4 x 4/0	28" x 48"							
2450	SINGLE/DOUBLE HUNG	CW3500 2/4 x 5/0	28" x 60-1/4"							
2460 2830	SINGLE/DOUBLE HUNG SINGLE/DOUBLE HUNG	CW3500 2/4 x 6/0 CW3500 2/8 x 3/0	28" x 72"							
2840	SINGLE/DOUBLE HUNG	CW3500 2/8 x 3/0	32" x 48"							
2850	SINGLE/DOUBLE HUNG	CW3500 2/8 x 5/0	32" x 60-1/4"							
* 2860	SINGLE/DOUBLE HUNG	CW3500 2/8 x 6/0	32" x 72"							
3030 3040	SINGLE/DOUBLE HUNG SINGLE/DOUBLE HUNG	CW3500 3/0 x 3/0 CW3500 3/0 x 4/0	36-1/4 x 36 36-1/4" x 48"							
* 3050	SINGLE/DOUBLE HUNG	I CW3500 3/0 x 5/0	I 36-1/4" x 60-1/4"I							
* 3060	SINGLE/DOUBLE HUNG	CW3500 3/0 x 6/0								
* 3070 * 3470	SINGLE/DOUBLE HUNG SINGLE/DOUBLE HUNG	CW3500 3/0 x 7/0 CW3500 3/4 x 7/0								
1050 FIXED	SINGLE/ BOOBLE HONG	910T 5/0 x 1/0	59-5/8" x 11-1/2"							
1640 FIXED		910T 4/0 x 1/8	1 47-1/4" x 19-1/2"							
2020 FIXED 2030 FIXED		CW3500 2/0 x 2/0 CW3500SL 2/0 x 3/	24" x 24" 0 24" x 36"							
2040 FIXED		CW3500SL 2/0 x 4/	0 24" x 48"							
2050 FIXED		CW3500SL 2/0 x 5/	0 24" x 60-1/4"							
2816 FIXED 2860 FIXED		910TSL 2/6 x 1/8 CW3500 3/0 x 6/0	29-1/4" x 19-1/2"							
3016 FIXED		910TSL 3/0 x 1/8	35-1/4" x 19-1/2"							
3020 FIXED		910TSL 3/0 x 2/0	35-1/4" x 23-1/2"							
3030 FIXED 3040 FIXED		CW3500P 3/0 x 3/0 CW3500P 3/0 x 4/0	36-1/4" x 36"							
3050 FIXED		CW3500P 3/0 x 4/0	36-1/4" x 46 36-1/4" x 60-1/4"							
3060 FIXED		CW3500P 3/0 x 6/0	36-1/4" x 72"							
3070 FIXED		CW3500P 3/0 x 7/0								
4010 FIXED 4020 FIXED		910T 4/0 x 1/0 910T 4/0 x 2/0	47-1/4" x 11-1/2" 47-1/4" x 23-1/2"							
4030 FIXED		CW3500P 4/0 x 3/0	48" x 36"							
4040 FIXED		CW3500P 4/0 x 4/0	48" x 48"							
4044 FIXED 4050 FIXED		CW3500P 4/0 x 4/4 CW3500P 4/0 x 5/0	48 X 52 48" x 60-1/4"							
4060 FIXED		CW3500P 4/0 x 6/0	48" x 72"							
4070 FIXED		CW3500P 4/0 x 7/0	48" x 84"							
5030 FIXED 5040 FIXED		CW3500P 5/0 x 3/0 CW3500P 5/0 x 4/0	60" X 36"							
5060 FIXED		CW3500P 5/0 x 6/0	60" x 72"							
5070 FIXED		CW3500P 5/0 x 7/0	60" x 84"							
6020 FIXED 6050 FIXED		910T 6/0 x 2/0 CW3500P 6/0 x 5/0	71-5/8" x 23-1/2"							
6060 FIXED		CW3500P 6/0 x 6/0	72" x 72"							
3'-0" HALF ROUN		CW3500 3/0 HC	36-1/4"							
4'-0" HALF ROUNI 5'-0" HALF ROUNI	D ว	CW3500 3/0 HC CW3500 3/0 HC	48"							
2020 OCTAGON		CW3500 3/0 HC CW3500 2/0 OCT	60" 24"							
2'-4" QUARTER RO	DUND	CW3500 2/4 QC	28"							
3'-0" QUARTER RO	DUND	CW3500 3/0 QC	36-1/4"							
			 							
<u> </u>			 							



Drees Homes

7701 Six Forks Road, Suite 132, Raleigh, NC 27615 PH:(919) 844-9288

Copyright © 2008, (2013) The Drees Company. All Rights Reserved. No portion of this material may be reproduced in any form or by any means, including photocopying, without the express written permission of the Drees Company. The Drees Company will vigorously prosecute any unauthorized use of this material.

Sheet Description:

WINDOW SCHEDULE

Sheet No.

MOULDED MILLWORK SCHEDULE

LAST REVISED 11/22/11

	HEADERS	1
Drees General Callout	Nuwood	Fypon
ARCHED HEADER D1	H8xxEFR	N/A
ARCHED HEADER D1K	H8xxEFKR	N/A
ARCHED HEADER D2	H8xxEFTR	N/A
ARCHED HEADER D2K	H8xxEFTKR	N/A
ARCHED HEADER D3	AH10xx	WCHSEGxxX10
ARCHED HEADER D3K	N/A	WCHSEGxxX10K
ARCHED HEADER D4	AR5xx	ARxxX6M
ARCHED HEADER D4K	AR5xxK	ARxxX6MK
ARCHED HEADER D5	AR10xxEC	ARxxX6METAR6C
ARCHED HEADER D5K	AR10xxECK	ARxxX6METAR6CK
ARCHED HEADER D6	AR10xxC	ARxxX10MC
ARCHED HEADER D6K	AR10xxCK	ARxxX10MCK
ARCHED HEADER D7K	H7xxEF-4K	N/A
ARCHED HEADER D8	AR14xxC	ARxxX14MC
ARCHED HEADER D8K	AR14xxCK	ARXXX14MCK
ARCHED HEADER D9	H9xxE	WCHARSxx13
CROSSHEAD A1	H9xx	WCHXXX9N
CROSSHEAD A1K	H9xxK	WCHXXX9NK
CROSSHEAD B1	H14xxBT	WCHXXX14BT
CROSSHEAD B1K	H14xxBTK	WCHXXX14BT WCHXXX14BTK
CROSSHEAD B2	H12xx	WCHXXX14BIK WCHXXX12
CROSSHEAD B2K	H12xxK	WCHXXX12 WCHXXX12K
CROSSHEAD C1	H18xxBT	WCHXXX12N WCHXXX14BT
CROSSHEAD C1K	H18XXBTK	WCHXXX14BT WCHXXX14BTK
CROSSHEAD C1K		LDCHxxX14B1K
	H18xxBT-PA H18xxBTK-PA	
CROSSHEAD C2K CROSSHEAD Z-E1-HDR		LDCHxxX18K
	Z-E1-HDR	Z-E1-HDR Z-E2-HDR
CROSSHEAD Z-E2-HDR	Z-E2-HDR	
CROSSHEAD Z-E3-HDR	Z-E3-HDR	Z-E3-HDR
CROSSHEAD Z-E3-ARCHHDR	Z-E3-ARCHHDR	Z-E3-ARCHHDR
CROSSHEAD Z-E3-CLHDR	Z-E3-CLHDR	Z-E3-CLHDR
CROSSHEAD Z-E5-HDR	Z-E5-HDR	Z-E5-HDR
WINDOW HEADER A1	H6xx	WCHxxX6
WINDOW HEADER A1K	H6xxK	WCHxxX6K
WINDOW HEADER B1	H9xx-2	WCHxxX9N
WINDOW HEADER B1K	H9xx-2K	WCHxxX9NK
WINDOW HEADER B2	H9xxBT	WCHxxX10NBT
WINDOW HEADER B2K	H9xxBTK	WCHxxX10NBTK
WINDOW HEADER C1	H9xx	CCAxxX10
WINDOW HEADER C1K	H9xxK	CCAxxX10K
WINDOW HEADER C2	H9xxT	WCHxxX9T
WINDOW HEADER C2K	H9xxTK	WCHxxX9TK
WINDOW HEADER C3	H12xxBT	WCHxxX10BT
WINDOW HEADER C3K	H12xxBTK	WCHxxX10BTK
WINDOW HEADER C4	H14xxBT	WCHxxX14BT
WINDOW HEADER D1	H7xxF-4	N/A
WINDOW HEADER D1K	H7xxF-4K	N/A
WINDOW HEADER D2K	H9xxK-1	N/A
WINDOW HEADER Z-W1	Z-W1	Z-W1
WINDOW HEADER Z-W3	Z-W3	Z-W3
WINDOW HEADER Z-W3K	Z-W3K	Z-W3K
WINDOW HEADER Z-W3D	Z-W3D	Z-W3D
WINDOW HEADER Z-W4	Z-W4	Z-W4
WINDOW HEADER Z-W4K	Z-W4K	Z-W4K
		<u> </u>
		<u> </u>
		<u> </u>
	<u> </u>	<u> </u>
		-
		-
		-
	1	

PILASTERS						
Drees General Callout	Nuwood	Fypon				
FLUTED PILASTER A1	PL7xxF	PIL7Xxx				
FLUTED PILASTER B1	PL9xxF	PIL9Xxx				
FLUTED PILASTER C1	PL11xxFM	PIL11Xxx				
Panel Pilaster A2	PL7xxP	PIL7XxxDP				
PANEL PILASTER B2	PL9xxP	PIL9XxxDP				
Panel Pilaster C2	PL11xxPM	PIL11XxxDP				
PILASTER D1	M311-9	PIL10XxxA				
PILASTER D2	M323-9	N/A				
PILASTER Z-E1-PIL	Z-E1-PIL	Z-E1-PlL				
PILASTER Z-E2-PIL	Z-E2-PIL	Z-E2-PIL				
PILASTER Z-E3-PIL	Z-E3-PIL	Z-E3-PIL				
PILASTER Z-PIL-EXT	Z-PIL-EXT	Z-PIL-EXT				
PLAIN PILASTER A3	PL7xxS	PIL7XxxP				
PLAIN PILASTER B3	PL9xxS	PIL9XxxP				
PLAIN PILASTER C3	PL11xxS	PIL11XxxP				
PLINTH D1	PF10	ADD "P" TO END OF PILASTER				
PLINTH D2	P14.5	N/A				
	LOUVERS					

Drees General Callout	Nuwood	Fypon	Mid-America
CATHEDRAL LOUVER D1	CLV1224	CLV12X24	
CATHEDRAL LOUVER D1T	CLV1224TRIM4	CLV12X24X4F	
CATHEDRAL LOUVER D2	CLV1432	CLV14X32	
CATHEDRAL LOUVER D2T	CLV1432TRIM4	CLV14X32X4F	00 44 1422
CATHEDRAL LOUVER D3	CLV2232	CLV22X32	
CATHEDRAL LOUVER D3T	CLV2232TRIM4	CLV22X32X4F	
HALF CIRCLE LOUVER D1	HRLV32	HRLV32X16	
HALF CIRCLE LOUVER D1T	HRLV32TRIM4	HRLV32X4F	
HALF CIRCLE LOUVER D2	HRLV36	HRLV36X18	
HALF CIRCLE LOUVER D2T	HRLV36TRIM4	HRLV36X4F	00 43 2234
OCTAGONAL LOUVER D1	OLV24	OLV24	
OCTAGONAL LOUVER D12	OLV24TRIM4	OLV24X4F	
OVAL LOUVER D1	OLV2537	OLV37X25	
OVAL LOUVER DIT	OLV2537TRIM4	OLV37X25X4F	
RECTANGUAR LOUVER D1	LV1224V	LV12X24	00 45 1218
RECTANGUAR LOUVER D1T	LV1224VTRIM4	LV12X24-4F	00 45 1218
RECTANGUAR LOUVER D2	LV1636V	LV16X36	
RECTANGUAR LOUVER D2T	LV1636VTRIM4	LV16X36-4F	
RECTANGUAR LOUVER D3	LV2436V	LV24X36	
RECTANGUAR LOUVER D3T	LV2436VTRIM4	LV24X36-4F	
RECTANGUAR LOUVER D4	LV2424V	LV24X24	
RECTANGUAR LOUVER D4T	LV2424VTRIM4	LV24X24-4F	
ROUND LOUVER D1	RLV18	RLV18	
ROUND LOUVER D1T	RLV18TRIM4	RLV18X4F	
ROUND LOUVER D2	RLV22	RLV22	
ROUND LOUVER D2T	RLV22TRIM4	RLV22X4F	
TRIANGULAR LOUVER D1		TRLVxxX36	00 47 0x0x
<u> </u>		1	

BRACKETS

Drees General Callout	Nuwood	Fypon
EXTERIOR BRACKET D1	BR437	N/A
EXTERIOR BRACKET D2	DB102	DTLB6X4X6
EXTERIOR BRACKET D3	BR304 (7" WIDE)	BKT24X24X7
EXTERIOR BRACKET D4	BR455	N/A
EXTERIOR BRACKET D5	BR300-1	BKT12X12X6
EXTERIOR BRACKET D6	BR300	BKT12X12
EXTERIOR BRACKET D7	BR409	BKT16X18X3
EXTERIOR BRACKET D8	BR413	DTLB5X5X3
EXTERIOR BRACKET D9	TBD	BKT11X20
EXTERIOR BRACKET D10	TBD	BKT12X24X3
EXTERIOR BRACKET D11	BR435	BKT25X27
EXTERIOR BRACKET D12	BR404	BKT16X30X4
EXTERIOR BRACKET D13	BR23.13x10.13x5.5	N/A
GABLE BRACKET D1	TBD	DTLB6X4X6R(OR L)PITCH
GABLE BRACKET D2	BR423-x:12	BKT5X20
GABLE BRACKET D3	BR424-x:12	BKT5X20 (CUT 2" PROJECTION)
		•

MOULDINGS					
Drees General Callout	Nuwood	Fypon			
BAND MOULD D1	M210-16	MLD612-12			
BAND MOULD D2	M301-16	MLD220-16			
BARGE MOULD D1	WM210	WM210			
CASE MOULD D1	M320-16	MLD226-16			
CASE MOULD D2	N/A	MLD244-12			
CROWN MOULD D1	M404-16	MLD572-16			
DENTIL MOULD D1	M105-16	MLD310-16			
DENTIL MOULD D2	M108-8	MLD353-8			
HALF ROUND MOULD D1	N/A	MLD605-12			
PANEL MOULD D1	M310-8 OR 16	MLD612-12			

PEDIMENTS / COMBO HEADERS

Drees General Callout	Nuwood	Fypon
BROW COMBO D1	BCxx	CSAPxx
PEAK PEDIMENT D1	Pxx-4 (6:12)	PCPxx
PEAK PEDIMENT Z-E1-PED	Z-E1-PED	Z-E1-PED
PEAKED COMBO D1	PCxx-4	CPCPxx
RAMS HEAD PEDIMENT D1	Rxx	RHPxx00
ROUND PEDIMENT D1	Bxx-4	PSPxx
SUNRISE COMBO D1	SCxx-4	CSPxx
VICTORIAN PEDIMENT D1	VPxx	DVPxx w/ SWDHxxXxx
	· · · · · · · · · · · · · · · · · · ·	

WINDOW DECORATION

Drees General Callout	Nuwood	Fypon
HALF CIRCLE SUNBURST D1	SPxxxx	SWDHxxXxx
PALLADIAN WINDOW D1	H9AR10-xx xx" FL/FR	ARxxX10MFLxxx
PALLADIAN WINDOW D1K	H9AR10-xxK xx" FL/FR	ARxxX10MFLxxx with K10TM
PALLADIAN WINDOW D2	H9AR10SPxxxx	ARxxX10MFLxxx with
		SWDHxxXxx
PALLADIAN WINDOW D2K	H9AR10SPxxxxK	ARxxX10MFLxxx with
		SWDHxxXxx and K10TM
PEAKED CAP HEADER D1	N/A	CHPCxxX15
PLAIN SEGMENT D1	SPxxxxP	PSPxx
SEGMENT SUNBURST D1	SPxxxx	SWDHxxXxx

ACCESSORIES

Drees General Callout	Nuwood	Fypon
GABLE D1	PGDx12	GPA (width X height)
KEYSTONE D1	KY14F-3	KY14
KEYSTONE D2	КҮНМ9F	К9М
WREATH D1	N/A	WAB34



MOULDED MILLWORK SCHEDULE

Sheet No.