



October 14, 2024

Robert Barefoot
12232 US-79 Bus. West
Clayton, NC 27520
Email: wrbarefoot@yahoo.com

Reference: Engineering Services
Permit # SFD2209-0009
891 Raynor Road
Spring Lake, NC 28390
TE&D Project No.: 2401-020836_A-R

As requested by the builder, a representative of Tyndall Engineering & Design, PA (TE&D) was on-site to observe the following items:

- 1) 3rd party inspection of footing projection repair installation.

The following conclusions and recommendations were noted:

- 1) Based on our observations and analysis, the footing projection repairs at the (2) specified piers were installed per our previous letter and meet the requirements of the 2018 NC Residential Building Code. No further modification is required.

We appreciate being able to assist you during this phase of the project. If you need further assistance or require additional information, please do not hesitate to contact us.

Sincerely,
Tyndall Engineering & Design

Tripp Amos
BH | 2401-020836_A-R

Prentice Tyndall Jr., P.E.





