

SOUTHEASTERN SOIL & ENVIRONMENTAL ASSOC., INC.

PROPOSED SUBSURFACE WASTE DISPOSAL SYSTEM DETAIL SHEET

SUBDIVISION: Liberty Meadows

LOT 75 416

INITIAL SYSTEM: ^{GRAV} APPROVED 25% REDUCTION

REPAIR ^{GRAV} Approved 25% Reduction

DISTRIBUTION: SERIAL

DISTRIBUTION SERIAL

BENCHMARK: 100.0

LOCATION FC TOS 75/76

NO. BEDROOMS: 4

LTAR 0.5 gpd/ft²

LINE	FLAG COLOR	ELEVATION	LENGTH
1	O	101.88	50
A {	2	G	101.67
	3	O	101.42
	4	G	101.42
	5a	D	101.33
			<u>240</u>
B {	5b	O	101.33
	6	G	101.33
	7	O	101.17
	8	G	101.00
			<u>240</u>

BY BC. Rayner

DATE 12/04/2021

TYPICAL PROFILE

THERE SHALL BE NO GRADING,

0-22 LS vfri gran

CUTTING, LOGGING OR OTHER SOIL

22-36 sec firm SBK

DISTURBANCE IN SEPTIC AREA

UR2 ≥ 25"

HEALTH DEPARTMENT USE ONLY.

DESIGNS DO NOT GUARANTEE FUNCTIONALITY

Liberty Meadow
Lot ~~75 & 76~~

46 + 47

