

January 25, 2023

Mr. Johnny Byrd
SBM Homes LLC
PO Box #71
Raleigh, NC 27602



Summary of 3rd Party Footing Inspection
139 Red Oak Drive
Spring Lake, North Carolina
Permit No.: 2209-0057
SUMMIT Project Number: 9498.F0001 (37280-01)

Dear Mr. Byrd:


On January 12 & 23, 2023, a representative of SUMMIT Engineering, Laboratory and Testing, Inc. (SUMMIT) visited the subject site for the purpose of performing a third-party footing inspection for the proposed residential structure. We note that a 3rd party evaluation was not requested on our January 12, 2023 site visit, however, footing depth and width measurements were still performed. The following is a summary of our onsite observations and evaluation.

The residential foundations were excavated approximately 16 inches wide and approximately 24 inches below the existing ground surface prior to our January 12, 2023 site visit. We returned January 23, 2023 as requested to perform a 3rd party evaluation. We note concrete had been placed. Based on the measurements and site observations made during both site visits, we observed that the exterior and interior wall foundations and lugs, were prepared per the structural plans provided onsite.

SUMMIT appreciates the opportunity to provide our professional services to you on this project. If you have any questions concerning the information in this report or if we can be of further service, please contact us.

Sincerely,
SUMMIT Engineering, Laboratory and Testing, Inc.

Jeff A. Taylor, P.E.
Geotechnical Engineer



A handwritten signature in black ink, appearing to read "Adam D. Perry".

Adam D. Perry, E.I.
Staff Professional