NC Registered Firm # F-1078



ECS Southeast, LLP 6151 Raeford Road, Suite A Fayetteville, NC 28304 9104013288 9103230539

LETTER OF TRANSMITTAL

March 1, 2023 Precision Custom Homes Raeford, NC 28376 ATTN: Shaun Gardner					RE: Liberty Meadows Lot 33 ECS Job # 33:6122-Y				
					Permits: Location:	32 Brewster Ct Cameron, NC 28326			
		X	Field Reports	X	For you	r use	X	As requested	
CC:	Precision Cust	om Hor	nes - Allen Peterson		Precision Custom Homes - Lauren Ceruti				

ENCL: Field Report # 1 3/1/2023

Flousat

Jack Cowsert, P.E. Office Manager

Aaron Kyle Adair Team Leader

Disclaimer

^{1.} This report (and any attachments) shall not be reproduced except in full without prior written approval of ECS.

^{2.} The information in this report relates only to the activities performed on the report date.

^{3.} Where appropriate, this report includes statements as to compliance with applicable project drawings, and specifications for the activities, performed on this report date.

^{4.} Incomplete or non-conforming work will be reported for future resolution.

^{5.} The results of samples and/or specimens obtained or prepared for subsequent laboratory testing will be presented in separate reports/documents.


Chargeable Ite	ems			12:00P	2:30P		
Trip Charges*	Tolls/Parking*	Mileage*	Time of	Arrival	Departur		
Remarks							
				0.00			
			Re Obs Time	0.00			
Contractor	Precision Custom Homes		Total	2.50 0.00 <u>0.00</u> 2.50			
Client	Precision Custom Homes		Lab Time Travel Time*				
Location	Cameron, NC		On-Site Time				
Project	Liberty Meadows Lot 33	Report No. Day & Date Weather	ہ Wednesday 3/1/2023 72 °/ Sunny				
	(910) 323-0539 [Fax]		Project No.	33:6122-Y 1			
	(910) 401-3288 [Phone]						
ELIQ	Fayetteville, NC 28304						
	6151 Raeford Road, Suite A			FIELD REPORT			
	ECS Southeast, LLP						

An ECS representative arrived on site, as requested, to check the bearing capacity of soils via hand auger/DCP method for monolithic slab foundation. The footings have not been excavated. Please see the attached sketch for location details.

A total of 4 hand auger/DCP evaluations were performed to a depth of approximately 3 feet below the current sub grade elevation.

Test results indicated that the materials in place (at the locations and elevations tested) did appear to be suitable to support the design bearing capacity 2,000 psf.

ECS will return, as requested, for additional services.



Report of Spread Footing - Foundation Observations

Project: Liberty Meadows Lot 33

32 Brewster Ct Location:

Cameron - Harnett - NC - 28326 Contractor: Precision Custom Homes

Project No.: 33:6122-Y

Day/Date: 3/1/2023

Footing Number	Location	Size (W x H x L)		Footing Bottom Elevation			Description of	Required Blow Counts	Design	
		Design	Actual	Design **		Description of Steel Placed	Description of Subgrade Material	# of Blows / Increment	Design Bearing Pressure	
1	S,E Corner	хх	хх	N/A	N/A		(0)/orange Sand (-2/-3) Tan Sand	6 (0)5,6,7(-1)11,9,10(-2) 9,11,10(-3)8,10,10	2000	
2	N,E Corner	х х	хх	N/A	N/A		(0)/-1 Tan Sand (-2/-3) tan sand Clay	6 (0)4,9,9(-1)7,8,8(-2) 14,14,16(-3)16,20,20	2000	
3	N.W Corner	хх	хх	N/A	N/A		(0)/-1 Orange Sand(-1/-3) tan Sand	6 (0)8,8,7(-1)10,11,12(-2) 12,11,14(-3)11,9,11	2000	
4	S.W Corner	х х	x x	N/A	N/A			6 (0)3,7,4(-1)7,8,10(-2) 11,11,13(-3)9,7,8	2000	

** SGE: Subgrade Elevation to be determined by surveyor.

By: George Pate Oxendine Jr.

ECS Southeast, LLP

NC Registered Firm # F-1078



Report of Spread Footing - Foundation Observations

Project:Liberty Meadows Lot 33Location:32 Brewster Ct
Cameron - Harnett - NC - 28326Contractor:Precision Custom Homes

Project No.: 33:6122-Y Day/Date: 3/1/2023

WO: 71007