Department of Environment, Health and Natural Resources Division of Environmental Health On-Site Wastewater Section Sheet: Property ID: Lot #: File #: Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner: GAT Applicant: Address: 57 H44Cock CT	.4.27		
Address: 51 HAACOCK CT	Date Evaluated: 10-18-22)	
Proposed Facility: SFD	Design Flow (.1949): 480 GPD	Property Size:	
Location of Site.	Property Recorded.		
	olic Individual Well	☐ Spring	Other
Evaluation Method: Auger Boring	g Pit Cut		
Type of Wastewater: Sev	wage	☐ Mixed	

P R O F I L E	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941			OTHER PROFILE FACTORS				
			Stru	941 cture/ xture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR
1,2	1	0-12	15	Gr	Fr/NS/NP/NXP	10 YR 7/2	>48"	_	_	PS.4
	2-5%	12-48	SCI	SBU	Filss/SP/XP	≥32"				PS.4 GOUP III
	i									
16		-								
		P								
	6.	L		,						

Description	Initial	Repair System	Other Factors (.1946):	es
	System		Site Classification (.1948):	1/
Available Space (.1945)			Evaluated By:	MI SEH
System Type(s) Yump	25% red	25% 100	Others Present:	I'M - KEID
Site LTAR	. 4	. 4		

COMMENTS: ____

LANDSCAPE POSITIONS	GROUP	TEXTURES	.1955 LTAR	CONSISTENCE MOIST	WET
R-RIDGE S-SHOULDER SLOPE L-LINEAR SLOPE	1	S-SAND LS-LOAMY SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE	NS-NON-STICKY SS-SLIGHTY STICKY
FS-FOOT SLOPE N-NOSE SLOPE H-HEAD SLOPE	П	SL-SANDY LOAM L-LOAM	0.8 - 0.6	FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	S-STICKY VS-VERY STICKY NP-NON-PLASTIC
CC-CONCLAVE SLOPE CV-CONVEX SLOPE T-TERRACE FP-FLOOD PLAN	Ш	SI-SILT SIL-SILT LOAM CL-CLAY LOAM SCL-SANDY CLAY LOAM	0.6 - 0.3		SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC
	IV	SIC-SILTY CLAY C-CLAY	0.4 - 0.1		

STRUCTURE
SG-SINGLE GRAIN
M- MASSIVE
CR-CRUMB
GR-GRANULAR
SBK-SUBANGULAR BLOCKY
ABK-ANGULAR BLOCKY
PL-PLATY

MINERALOGY SLIGHTLY EXPANSIVE

SC-SANDY CLAY

EXPANSIVE

