

May 2, 2023

On Top Building Company, LLC 2393 Twin Acres Road Clayton, NC 27520

Re: Oakdale plan (200116B)

Hey Brandie,

Per our conversation about the Oakdale plan and the H-2 notation at the side window in Bedroom 3 that is our old notation referring to a (2) 2 x 6 header. That was left on the plan by mistake when the plan was updated. Please ignore that notation and refer to the "Exterior Headers" chart on that page. The correct heder for that window should be (2) 2 x 6.

Thanks

Mike Haynes

Haynes Home Plans, Inc.