Department of Environment, Health and Natural Resources Division of Environmental Health On-Site Wastewater Section

Sheet: Property ID: Lot #: File #:

Code:

SOIL/SITE EVALUATION

for ON-SITE WASTEWATER SYSTEM
Herring Carlot
Applicant:

Date Evaluated: //- 4-72 Design Flow (.1949): 480 GPD Address: 125 Grand Griffen Proposed Facility: SED

Property Size: Property Recorded:

Location of Site: ☑ Public ☐ Individual Water Supply:

☐ Spring ☐ Cut

Other

Evaluation Method: Auger Boring Type of Wastewater:

Pit Industrial Process Sewage

☐ Mixed

P R O F I L E	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR
1+2	L	0-8	15 Gr	Frhshopuxe	10 yR 7/2	>48"	_	-	PS.4 Group III
	2-5%	8.48	5(1 5Bh	F. Isi/selsxe	10 ype 7/2				TIL
				-					
						*			
					1				
					19				
							-		

Description	Initial	Repair System
	System	
Available Space (.1945)		
System Type(s) /V-P	25% 120	25% 120
Site LTAR	. 4	. 4


Other Factors (.1946): Site Classification (.1948): Evaluated By:

Others Present:

MAREH

COMMENTS: \_\_\_\_

LANDSCAPE POSITIONS	GROUP	TEXTURES	. <u>1955 LTAR</u>	CONSISTENCE MOIST	WET
R-RIDGE S-SHOULDER SLOPE L-LINEAR SLOPE	1	S-SAND LS-LOAMY SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE	NS-NON-STICKY SS-SLIGHTY STICKY
FS-FOOT SLOPE N-NOSE SLOPE H-HEAD SLOPE	II	SL-SANDY LOAM L-LOAM	0.8 - 0.6	FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	S-STICKY VS-VERY STICKY NP-NON-PLASTIC
CC-CONCLAVE SLOPE CV-CONVEX SLOPE T-TERRACE FP-FLOOD PLAN	III	SI-SILT SIL-SILT LOAM CL-CLAY LOAM SCL-SANDY CLAY LOAM	0.6 - 0.3		SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC
	IV	SIC-SILTY CLAY C-CLAY SC-SANDY CLAY	0.4 - 0.1		
STRUCTURE SG-SINGLE GRAIN M- MASSIVE		MINERALOGY SLIGHTLY EXPANSIVE			
CR-CRUMB GR-GRANULAR SBK-SUBANGULAR BLOCKY ABK-ANGULAR BLOCKY PL-PLATY		EXPANSIVE			



Grand Griffon Way