

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: 3 BORM Design Flow (.1949): 360 gpd Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L5 S-7	0-12	G LS	VFR NS/AP					
		12-36	SBK SCL	FR SS/SF	10YR 7/2 @ 32"				PS .4 PS .35
2		0-12	G LS	VFR NS/AP					
		12-32	SBK SCL	F SS/SF	10YR 7/2 @ 26"				PS .35
3		0-10	G LS	VFR NS/AP					
		10-32	SBK SCL	F SS/SF	5YR 2 @ 26"				PS .35

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): Evaluated By: Others Present:
Available Space (.1945)	✓	✓	
System Type(s)	PUMP AND TREATMENT		
Site LTAR	PS	.35	

