

Joe E Godwin Sr. , P.E., P.L.S.

Jason E Godwin , P.L.S.



1403 NC Highway 50 South
Benson, North Carolina 27504
919.894.7765

Email: general@enochengineers.com

www.enochengineers.com

MATERIALS & TEST DIVISION

FIELD REPORT

PROJECT

CLIENT:	KCC CONSTRUCTION	DATE:	3.7.23
PROJECT:	RESI STEM WALL FILL	CONTRACTOR:	M. WILLIAMS
ADDRESS:	531 OLD STAGE RD N	TECHNICIAN:	BH
LOT #:	COATS,NC		

TEST SUMMARY

PERFORMED NDT ON STEM WALL FILL MATERIAL AT SITE NOTED ABOVE USING A TARGET DENSITY OF 115PCF. SOILS CONFIRMED A COMPACTION GREATER THAN OR EQUAL TO 95%.

TESTING RESULTS

SERVICE PERFORMED	TEST NO.	COMP %	WD PCF	DD PCF	MOISTURE %
NDT	1	100+	115.1	119.2	3.4

RETURN VISIT REQUIRED

YES
NO

TECHNICIAN:

Disclaimer:

Soils & Material inspections, testing results and on-site determinations contained in this report become void after 30 days of non-use of this report and/or following any inclement weather which causes structural soil or material deterioration. Additional testing will be required following a voided report determined by a North Carolina Building Code enforcement official or Enoch Engineers P.A. The client/contractor is responsible for notifying Enoch Engineers P.A. of any soil & material condition changes which could void this report.